




FUEL REPORT

Sample Rating Trend

NORMAL



Area
Texas City
 Machine Id
[Texas City] Diesel - #2 Port
 Component
Diesel Fuel
 Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (4045 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no indication of any contamination in the fuel.

Fuel Condition

The condition of the fuel is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0735699	WC0719570	WC0643293
Sample Date	Client Info	16 Oct 2023	15 Jan 2023	01 Aug 2022
Machine Age	hrs	0	0	0
Sample Status		NORMAL	NORMAL	NORMAL

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2
Visc @ 40°C	cSt	2.31	2.3	---

SULFUR CONTENT

method	limit/base	current	history1	history2
Sulfur	ppm	20	0	52

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	2	0	0
Sodium	ppm	<1	0	<1
Potassium	ppm	0	<1	0
Water	%	0.005	0.003	0.003
ppm Water	ppm	58.5	32.7	31.1

HEAVY METALS


method	limit/base	current	history1	history2
Aluminum	ppm	0	0	<1
Nickel	ppm	0	0	0
Lead	ppm	0	0	0
Vanadium	ppm	0	0	0
Iron	ppm	0	0	0
Calcium	ppm	0	0	0
Magnesium	ppm	0	<1	0
Phosphorus	ppm	0	5	1
Zinc	ppm	0	0	0

SAMPLE IMAGES




method	limit/base	current	history1	history2
Color				
Bottom				



FUEL REPORT



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0735699 **Received** : 06 Nov 2023
Lab Number : 05999488 **Diagnosed** : 14 Nov 2023
Unique Number : 10727848 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

MARATHON PETROLEUM CO.
 101 12TH ST
 CATLETTSBURG, KY
 US 41169

Contact: CORY GUMBERT
 cagumbert@marathonpetroleum.com

T: (606)585-3950

F: x: