

FUEL REPORT

Area [3096816] SD0030 50003DJ6162 (S/N 91 Component

Diesel Fuel NOT GIVEN (--- QTS)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

Free water present. There is no bacteria or fungus (yeast and/or mold) indicated in the sample.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

REPORT						WATER
9113309)						
				Nov2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number Sample Date Machine Age Sample Status	hrs	Client Info Client Info Client Info		DC0031449 05 Nov 2023 342 ABNORMAL	 	
PHYSICAL PROP	PERTIES	method	limit/base	current	history1	history2
ASTM Color Visc @ 40°C	scalar cSt	*ASTM D1500 ASTM D445		L3.0 2.4		
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur Sulfur (UVF)	ppm ppm	ASTM D5185m ASTM D5453		8 11		
IGNITION QUALI	TY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		37.0		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304		0.00		
ppm Water	ppm	ASTM D6304	<500	0.00		
% Gasoline	%	*In-House	<0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		
MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	WC-Method	>=100000	0		
Yeast	CFU/ml	WC-Method	>=100000	0		
Mold	Colonies	WC-Method	MODER			
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0		
Nickel	ppm	ASTM D5185m	<0.1	0		
Lead	ppm	ASTM D5185m	<0.1	0		
Vanadium	ppm	ASTM D5185m	<0.1	0		
Iron	ppm	ASTM D5185m	<0.1	0		
Calcium	ppm	ASTM D5185m	<0.1	0		
Magnesium	ppm	ASTM D5185m	<0.1	0		
Phosphorus	ppm	ASTM D5185m	<0.1	0		
Zinc	ppm	ASTM D5185m	<0.1	0		
SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Color				TTUE .	no image	no image
Bottom					no image	no image

Sample Rating Trend


WATER

Contact/Location: LESLIE SNURR - KELOWI



FUEL REPORT

GRAPHS



	à	Laboratory	: WearCheck USA - 501 Madison Ave., Cary, NC 27513			KELLY GENERATOR & EQUIPMENT INC
	ANAB	Sample No.	: DC0031449	Received	: 06 Nov 2023	1955 DALE LN
		Lab Number	: 05999497	Diagnosed	: 15 Nov 2023	OWINGS, MD
- XTRA - 755	TESTING LABORATORY	Unique Number	: 10727857	Diagnostician	: Doug Bogart	US 20736
	Certificate L2367	Contact: LESLIE SNURR				
	To discuss thi	LSNURR@KGE.COM				
	* - Denotes te	T: (410)257-5225				
	Statements of	<i>D6:2012)</i> F: (410)257-5227				

Contact/Location: LESLIE SNURR - KELOWI

Pensky-Martens Flash Point (°C)

10

8

C ature C

-2

-6

-8

-10

Nov5/23

Page 2 of 2

Nov5/23 -