PROBLEM SUMMARY

Area 075 G5 [2994724] B5 Blower

RENSIC

Component Inboard Bearing Fluid SHELL CORENA S4 R46 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

If possible filter the oil using B6=75 or better quality filter elements. No other corrective action at this time.

Sample Rating Trend ISO ISO ISO

Sample Status			ABNORMAL	NORMAL
Particles >4µm	ASTM D7647	>10000	<u> </u>	2049
Particles >6µm	ASTM D7647	>2500	6 5502	243
Particles >14µm	ASTM D7647	>160	<u> </u>	37
Particles >21um	ASTM D7647	>40	396	10

ISO 4406 (c) >20/18/14 A 22/20/17

ASTM D7647 >10

Customer Id: HEXGEI Sample No.: PLS0000675 Lab Number: 05999784 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Mike Johnson +1 (615)771-6030 <u>mike.johnson@amrri.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

PROBLEMATIC TEST RESULTS

Particles >38µm

Oil Cleanliness

SEVERE

3587

813

89

24

2

19/17/14

1

18/15/12

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

07 Oct 2022 Diag: Mike Johnson



Oil is acceptable for continued use. Resample at next normal interval.Wear particles are low and acceptable. Contamination is on par with new unfiltered oil. Fluid health is acceptable for continued use.

02 Nov 2021 Diag: Mike Johnson

21 Aug 2018 Diag:



Emulsified water present in sample. Investigate possible sources of water contamination. Consider water filtration if oil is regularly subjected to water contamination. Consider changing oil if water filtration not possible. Resample at next normal interval.Wear metals are low and acceptable. Contamination is on par with new unfiltered oil. Water levels are above 1000 ppm. Fluid health is acceptable for continued use.



view report



No corrective action at this time. Continue to monitor. The wear rates are low and normal. Particle contamination levels have improved, but are still elevated. Concentrations at this level can impact long term reliability of mechanical systems. Fluid health indicators suggest that the oil is acceptable for continued use.









OIL ANALYSIS REPORT

Area 075 G5 [2994724] B5 Blower Component

Inboard Bearing Fluid SHELL CORENA S4 R46 (--- GAL)

DIAGNOSIS

A Recommendation

If possible filter the oil using B6=75 or better quality filter elements. No other corrective action at this time.

Wear

The wear rate is low and steady.

Contamination

The solid particulate contaminant load is slightly elevated.

Fluid Condition

Fluid health indicators suggest the oil is suitable for continued use.



SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PLS0000675	PLS05685062	PLS05404545
Sample Date		Client Info		11 Oct 2023	07 Oct 2022	02 Nov 2021
Machine Age	yrs	Client Info		12	0	6
Oil Age	yrs	Client Info		1	8	1
Oil Changed		Client Info		Not Changd	N/A	N/A
Sample Status				ABNORMAL	NORMAL	SEVERE
CONTAMINATION	١	method	limit/base	current	history1	history2
Water		WC Method	>2	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		19	10	18
Iron	ppm	ASTM D5185m	>20	2	<1	2
Chromium	ppm	ASTM D5185m	>20	0	0	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	0	<1	<1
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>20	0	<1	<1
Tin	ppm	ASTM D5185m	>20	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		140	77	80
Zinc	ppm	ASTM D5185m		0	18	2
Sulfur	ppm	ASTM D5185m		120	204	236
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	<1	0
Sodium	ppm	ASTM D5185m		<1	4	3
Potassium	ppm	ASTM D5185m	>20	0	0	0
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0.1	0
Nitration	Abs/cm	*ASTM D7624		4.3	5.1	4.9
Sulfation	Abs/.1mm	*ASTM D7415		9.3	8.9	8.5



OIL ANALYSIS REPORT

FLUID CLEANLINESS





50 Π

50

Viscosity @ 40°C

Particles >4µm		ASTM D7647	>10000	A 35057	2049	3587
Particles >6µm		ASTM D7647	>2500	<u> </u>	243	813
Particles >14µm		ASTM D7647	>160	A 701	37	89
Particles >21µm		ASTM D7647	>40	<mark>/</mark> 396	10	24
Particles >38µm		ASTM D7647	>10	<u> </u>	1	2
Particles >71µm		ASTM D7647	>3	2	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/14	<u> </u>	18/15/12	19/17/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414		2.7	3.6	3.3
Acid Number (AN)	mg KOH/g	ASTM D8045		0.37	0.23	0.237
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2	NEG	NEG	▲ 0.2%
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	42.3	47.0	47.7	47.0
	001	//01/11/01/10				

limit/base

current

method

history1

history2

Bottom

Received

Diagnosed

Oct11/23

Color



: WearCheck USA - 501 Madison Ave., Cary, NC 27513 **HEXION INC - GONZALES PLANT** : 06 Nov 2023 4338 HWY 73 : 20 Nov 2023 GEISMAR, LA Diagnostician : Mike Johnson US 70734 Contact: Shannon Ourso shannon.ourso@hexion.com;mike.johnson@amrri.com Т: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: