

PROBLEM SUMMARY

[181963-N2STV4W] Machine Id HYDRO TURBINE UNIT 2


Component
Turbino Poorir

Turbine Bearing

SHELL TURBO T ISO 68 (30 GAL)

Sample Rating Trend ISO George 3

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ABNORMAL					
Particles >4µm	ASTM D7647	>2500	A 7457					
Particles >6µm	ASTM D7647	>320	885					
Oil Cleanliness	ISO 4406 (c)	>18/15/13	<u>^</u> 20/17/12					
PrtFilter			9	no image	no image			

Customer Id: USACLI Sample No.: PH05999804 Lab Number: 05999804 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Filter			?	We recommend you service the filters on this component if applicable.			

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

[181963-N2STV4W] **HYDRO TURBINE UNIT 2**

Turbine Bearing

SHELL TURBO T ISO 68 (30 GAL)

Sample Rating Trend



DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination


There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Oct2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PH05999804		
Sample Date		Client Info		31 Oct 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1		
Chromium	ppm	ASTM D5185m	>20	0		
Nickel	ppm	ASTM D5185m	>20	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>20	0		
Lead	ppm	ASTM D5185m	>20	<1		
Copper	ppm	ASTM D5185m	>20	0		
Tin	ppm	ASTM D5185m	>20	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		6		
Phosphorus	ppm	ASTM D5185m		14		
Zinc	ppm	ASTM D5185m		9		
Sulfur	ppm	ASTM D5185m		230		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2		
Sodium	ppm	ASTM D5185m		6		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	<u> </u>		
Particles >6µm		ASTM D7647	>320	A 885		
Particles >14µm		ASTM D7647	>80	23		
Particles >21µm		ASTM D7647	>20	4		
Particles >38μm		ASTM D7647	>4	0		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>18/15/13	<u>^</u> 20/17/12		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2


Acid Number (AN) mg KOH/g ASTM D8045 .05



0.091



OIL ANALYSIS REPORT





Laboratory Sample No. Lab Number **Unique Number**

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PH05999804

: 05999804

: 10728164

Received : 06 Nov 2023 Diagnosed : 08 Nov 2023 : Jonathan Hester Diagnostician

Test Package : PLANT (Additional Tests: PrtFilter) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

USACE WHITNEY POWER PLANT

285 CR 3602 CLIFTON, TX US 76634 Contact: CHAD BRUNO

chad.j.bruno@usace.army.mil

T: (254)622-3268