PROBLEM SUMMARY

Sample Rating Trend



WATER

Machine Id
KAESER SK 15 5262039 (S/N 1751)
Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ATTENTION
Water	%	ASTM D6304	>0.05	▲ **0.154**	0.010	0.014
ppm Water	ppm	ASTM D6304	>500	▲ **1540**	107.0	141.6
Silt	scalar	*Visual	NONE	▲ **MODER**	NONE	NONE
Debris	scalar	*Visual	NONE	▲ **MODER**	▲ MODER	LIGHT
Emulsified Water	scalar	*Visual	>0.05	▲ **0.2%**	NEG	NEG

Customer Id: PWSCHA
Sample No.: KCPA006462
Lab Number: 05999860
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldridge +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

27 Jan 2023 Diag: Doug Bogart

VIS DEBRIS

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

16 May 2022 Diag: Don Baldridge

ISO

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

20 Sep 2021 Diag: Doug Bogart

ISO

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT

Sample Rating Trend



WATER

Machine Id
KAESER SK 15 5262039 (S/N 1751)
Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation
The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear
All component wear rates are normal.

Contamination
There is a moderate amount of visible silt present in the sample. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil.

Fluid Condition
The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**KCPA006462**	KCP55802	KCP51491
Sample Date		Client Info		**31 Oct 2023**	27 Jan 2023	16 May 2022
Machine Age	hrs	Client Info		**32653**	31765	27469
Oil Age	hrs	Client Info		**0**	4296	4000
Oil Changed		Client Info		**N/A**	N/A	Not Changd
Sample Status				**ABNORMAL**	ABNORMAL	ATTENTION

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	**0**	<1	<1
Chromium	ppm	ASTM D5185m	>10	**0**	0	0
Nickel	ppm	ASTM D5185m	>3	**0**	0	0
Titanium	ppm	ASTM D5185m	>3	**0**	0	0
Silver	ppm	ASTM D5185m	>2	**0**	0	<1
Aluminum	ppm	ASTM D5185m	>10	**0**	0	<1
Lead	ppm	ASTM D5185m	>10	**0**	0	0
Copper	ppm	ASTM D5185m	>50	**4**	20	7
Tin	ppm	ASTM D5185m	>10	**0**	0	0
Antimony	ppm	ASTM D5185m		**---**	---	---
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	<1
Barium	ppm	ASTM D5185m	90	**0**	2	0
Molybdenum	ppm	ASTM D5185m		**0**	0	0
Manganese	ppm	ASTM D5185m		**0**	0	0
Magnesium	ppm	ASTM D5185m	90	**35**	6	15
Calcium	ppm	ASTM D5185m	2	**2**	0	0
Phosphorus	ppm	ASTM D5185m		**3**	2	9
Zinc	ppm	ASTM D5185m		**22**	44	23
Sulfur	ppm	ASTM D5185m		**17594**	16033	15832

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	**0**	2	1
Sodium	ppm	ASTM D5185m		**11**	1	5
Potassium	ppm	ASTM D5185m	>20	**0**	<1	0
Water	%	ASTM D6304	>0.05	▲ **0.154**	0.010	0.014
ppm Water	ppm	ASTM D6304	>500	▲ **1540**	107.0	141.6

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		**---**	---	5810
Particles >6µm		ASTM D7647	>1300	**---**	---	▲ 1660
Particles >14µm		ASTM D7647	>80	**---**	---	▲ 95
Particles >21µm		ASTM D7647	>20	**---**	---	19
Particles >38µm		ASTM D7647	>4	**---**	---	0
Particles >71µm		ASTM D7647	>3	**---**	---	0
Oil Cleanliness		ISO 4406 (c)	>17/13	**---**	---	▲ 18/14

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	**0.36**	0.33	0.37

KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	▲ **MODER**	NONE	NONE
Debris	scalar	*Visual	NONE	▲ **MODER**	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	▲ **0.2%**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	**43.7**	44.3	44.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS









Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA006462 **Received** : 06 Nov 2023
Lab Number : 05999860 **Diagnosed** : 08 Nov 2023
Unique Number : 10728220 **Diagnostician** : Don Baldridge
Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

PWS INTERNATIONAL
2910 HORSESHOE LN
CHARLOTTE, NC
US 28208
Contact:

T:
F: