


PROBLEM SUMMARY

Sample Rating Trend

ISO




Area
Marcus Hook/Cryogenic/Compressor
 Machine Id
CRYOGENIC COMPRESSOR 20-C-301B
 Component
Rotary Compressor
 Fluid
SHELL TURBO S4 GX 46 (--- GAL)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time.
 Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status	ASTM D7647	ASTM D7647	ABNORMAL	ATTENTION	NORMAL
Particles >4µm	>2500	▲ 5311	1020	614	
Particles >6µm	>320	▲ 1307	▲ 333	114	
Particles >14µm	>80	▲ 179	41	10	
Particles >21µm	>20	▲ 74	16	3	
Oil Cleanliness	ISO 4406 (c)	>18/15/13	▲ 20/18/15	▲ 17/16/13	16/14/10

Customer Id: ETCMHOOK
 Sample No.: TO60001811
 Lab Number: 05999941
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

25 Apr 2023 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



02 Nov 2022 Diag: Jonathan Hester

NORMAL




Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area
Marcus Hook/Cryogenic/Compressor
 Machine Id
CRYOGENIC COMPRESSOR 20-C-301B
 Component
Rotary Compressor
 Fluid
SHELL TURBO S4 GX 46 (--- GAL)



DIAGNOSIS

- Recommendation**
No corrective action is recommended at this time. Resample at the next service interval to monitor.
- Wear**
All component wear rates are normal.
- Contamination**
There is a high amount of particulates present in the oil.
- Fluid Condition**
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO60001811	TO90003023	TO90002783
Sample Date	Client Info	05 Nov 2023	25 Apr 2023	02 Nov 2022
Machine Age	hrs Client Info	0	0	0
Oil Age	hrs Client Info	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ATTENTION	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >70	0	0	0
Chromium	ppm ASTM D5185m >10	0	0	0
Nickel	ppm ASTM D5185m	0	0	0
Titanium	ppm ASTM D5185m	0	0	0
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m >3	0	0	0
Lead	ppm ASTM D5185m >4	0	0	0
Copper	ppm ASTM D5185m >20	0	0	0
Tin	ppm ASTM D5185m >3	0	0	0
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 0	0	0	0
Barium	ppm ASTM D5185m 0	0	0	0
Molybdenum	ppm ASTM D5185m 0	0	0	0
Manganese	ppm ASTM D5185m 0	0	0	0
Magnesium	ppm ASTM D5185m 0	0	0	0
Calcium	ppm ASTM D5185m 0	<1	0	0
Phosphorus	ppm ASTM D5185m 75	48	69	86
Zinc	ppm ASTM D5185m 10	0	0	0
Sulfur	ppm ASTM D5185m 75	46	63	0

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >45	<1	<1	<1
Sodium	ppm ASTM D5185m	2	0	<1
Potassium	ppm ASTM D5185m >20	0	<1	0
Water	% ASTM D6304 >0.6	0.002	0.002	0.175
ppm Water	ppm ASTM D6304	22.4	21.3	1750

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >2500	▲ 5311	1020	614
Particles >6µm	ASTM D7647 >320	▲ 1307	▲ 333	114
Particles >14µm	ASTM D7647 >80	▲ 179	41	10
Particles >21µm	ASTM D7647 >20	▲ 74	16	3
Particles >38µm	ASTM D7647 >4	4	4	0
Particles >71µm	ASTM D7647 >3	0	0	0
Oil Cleanliness	ISO 4406 (c) >18/15/13	▲ 20/18/15	▲ 17/16/13	16/14/10

FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 0.15	0.073	0.108	0.12

OIL ANALYSIS REPORT


▲ Particle Trend




Water (KF)




Viscosity @ 100°C



Water (KF)



Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	43.5	44.0	43.7
Visc @ 100°C	cSt	ASTM D445	7.50	7.5	7.6
Viscosity Index (VI)	Scale	ASTM D2270	139	136	142

SAMPLE IMAGES


Color




Bottom

GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO60001811 **Received** : 06 Nov 2023
Lab Number : 05999941 **Diagnosed** : 13 Nov 2023
Unique Number : 10728301 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ENERGY TRANSFER - MARCUS HOOK
 2ND & GREEN STREETS
 MARCUS HOOK, PA
 US 19061
 Contact: CHRISTOPHER HOFFA
 christopher.hoffa@energytransfer.com

T:
F: