



Area  
**Marcus Hook/Cryogenic/Compressor**  
 Machine Id  
**CRYOGENIC COMPRESSOR 50-C-101E**  
 Component  
**Rotary Compressor**  
 Fluid  
**ISO 100 (220 GAL)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time.  
 Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	ABNORMAL	ABNORMAL
Particles >6µm	ASTM D7647 >320	▲ 419	▲ 1027	▲ 8026
Oil Cleanliness	ISO 4406 (c) >18/15/13	▲ 18/16/12	▲ 20/17/12	▲ 23/20/15

Customer Id: ETCMHOOK  
 Sample No.: TO60001822  
 Lab Number: 05999966  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 25 Apr 2023 Diag: Don Baldrige

#### ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 02 Nov 2022 Diag: Jonathan Hester

#### VISCOSITY



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The oil viscosity is higher than normal. Confirm oil type. The AN level is acceptable for this fluid.

view report



### 03 May 2022 Diag: Don Baldrige

#### VISCOSITY




We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The oil viscosity is higher than normal. Confirm oil type. The AN level is acceptable for this fluid.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



Area  
**Marcus Hook/Cryogenic/Compressor**  
 Machine Id  
**CRYOGENIC COMPRESSOR 50-C-101E**  
 Component  
**Rotary Compressor**  
 Fluid  
**ISO 100 (220 GAL)**

## DIAGNOSIS

**Recommendation**  
 No corrective action is recommended at this time. Resample at the next service interval to monitor.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

**Fluid Condition**  
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>TO60001822</b>	TO90003048	TO90002745
Sample Date	Client Info	<b>05 Nov 2023</b>	25 Apr 2023	02 Nov 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ATTENTION</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >70	<b>1</b>	3	5
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >3	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >4	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >20	<b>0</b>	0	0
Tin	ppm	ASTM D5185m >3	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m	<b>0</b>	<1	0
Calcium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Phosphorus	ppm	ASTM D5185m	<b>&lt;1</b>	0	19
Zinc	ppm	ASTM D5185m	<b>0</b>	1	0
Sulfur	ppm	ASTM D5185m	<b>4</b>	0	0

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >45	<b>2</b>	2	4
Sodium	ppm	ASTM D5185m	<b>0</b>	0	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	0
Water	%	ASTM D6304 >0.6	<b>0.003</b>	0.001	0.119
ppm Water	ppm	ASTM D6304	<b>25.4</b>	9.2	1190

## FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >2500	<b>1602</b>	▲ 5523	▲ 41694
Particles >6µm	ASTM D7647 >320	▲ <b>419</b>	▲ 1027	▲ 8026
Particles >14µm	ASTM D7647 >80	<b>25</b>	25	▲ 176
Particles >21µm	ASTM D7647 >20	<b>4</b>	4	17
Particles >38µm	ASTM D7647 >4	<b>0</b>	1	1
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >18/15/13	▲ <b>18/16/12</b>	▲ 20/17/12	▲ 23/20/15

## FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.015</b>	0.014	0.055

# OIL ANALYSIS REPORT


## Particle Trend




## Water (KF)




## Viscosity @ 100°C



## Water (KF)



## Viscosity @ 100°C




PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

PARAMETER	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	99.9	▲ 102
Visc @ 100°C	cSt	ASTM D445	11.5	15.9	▲ 16.2
Viscosity Index (VI)	Scale	ASTM D2270	102	170	171

## SAMPLE IMAGES


Color




Bottom

## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO60001822 **Received** : 06 Nov 2023  
**Lab Number** : 05999966 **Diagnosed** : 08 Nov 2023  
**Unique Number** : 10728326 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**ENERGY TRANSFER - MARCUS HOOK**  
 2ND & GREEN STREETS  
 MARCUS HOOK, PA  
 US 19061  
 Contact: CHRISTOPHER HOFFA  
 christopher.hoffa@energytransfer.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: