




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
NEUMAN & ESSER C-6004A (S/N 909000794)

Component
Reciprocating Compressor

Fluid
TOTAL FINA CARTER SP ISO 150 (22 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0817279	WC0817275	---
Sample Date	Client Info		06 Nov 2023	11 May 2023	---
Machine Age	hrs	Client Info	4505	3376	---
Oil Age	hrs	Client Info	1500	376	---
Oil Changed		Client Info	N/A	Changed	---
Sample Status			NORMAL	NORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	<1	---
Chromium	ppm	ASTM D5185m	>10	0	0	---
Nickel	ppm	ASTM D5185m		0	0	---
Titanium	ppm	ASTM D5185m		0	<1	---
Silver	ppm	ASTM D5185m		0	0	---
Aluminum	ppm	ASTM D5185m	>25	0	3	---
Lead	ppm	ASTM D5185m	>25	6	6	---
Copper	ppm	ASTM D5185m	>50	0	0	---
Tin	ppm	ASTM D5185m	>15	<1	<1	---
Vanadium	ppm	ASTM D5185m		0	0	---
Cadmium	ppm	ASTM D5185m		0	0	---

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		14	14	---
Barium	ppm	ASTM D5185m		0	0	---
Molybdenum	ppm	ASTM D5185m		0	0	---
Manganese	ppm	ASTM D5185m		0	<1	---
Magnesium	ppm	ASTM D5185m		<1	<1	---
Calcium	ppm	ASTM D5185m		20	15	---
Phosphorus	ppm	ASTM D5185m		431	434	---
Zinc	ppm	ASTM D5185m		6	1	---
Sulfur	ppm	ASTM D5185m		6595	6600	---

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	36	10	---
Sodium	ppm	ASTM D5185m		<1	0	---
Potassium	ppm	ASTM D5185m	>20	3	<1	---

FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	816	4690	---
Particles >6µm	ASTM D7647	>2500	189	1023	---
Particles >14µm	ASTM D7647	>320	10	89	---
Particles >21µm	ASTM D7647	>80	3	27	---
Particles >38µm	ASTM D7647	>20	1	1	---
Particles >71µm	ASTM D7647	>4	1	1	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	17/15/10	19/17/14	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.66	1.10	---




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 142	158	156	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0817279 Received : 06 Nov 2023
 Lab Number : 05999982 Diagnosed : 13 Nov 2023
 Unique Number : 10728342 Diagnostician : Angela Borella
 Test Package : IND 2 (Additional Tests: PRTCOUNT)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

PIEDMONT NATURAL GAS / DUKE ENERGY
 680 REV BILL RD
 MAXTON, NC
 US 28364
 Contact: ANDREW CAVENAUGH
 andrew.cavenaugh@duke-energy.com

T: (910)227-0302

F: