




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**NEUMAN & ESSER C-6004C (S/N 909000796)**

Component  
**Reciprocating Compressor**

Fluid  
**TOTAL FINA CARTER SP ISO 150 (22 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0817277</b>	WC0817274	---
Sample Date	Client Info			<b>06 Nov 2023</b>	11 May 2023	---
Machine Age	hrs	Client Info		<b>4218</b>	0	---
Oil Age	hrs	Client Info		<b>1300</b>	534	---
Oil Changed		Client Info		<b>N/A</b>	Changed	---
Sample Status				<b>NORMAL</b>	NORMAL	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>0</b>	<1	---
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	---
Nickel	ppm	ASTM D5185m		<b>0</b>	0	---
Titanium	ppm	ASTM D5185m		<b>0</b>	<1	---
Silver	ppm	ASTM D5185m		<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m	>25	<b>0</b>	3	---
Lead	ppm	ASTM D5185m	>25	<b>8</b>	5	---
Copper	ppm	ASTM D5185m	>50	<b>0</b>	0	---
Tin	ppm	ASTM D5185m	>15	<b>&lt;1</b>	<1	---
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	---
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>16</b>	16	---
Barium	ppm	ASTM D5185m		<b>0</b>	0	---
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	---
Manganese	ppm	ASTM D5185m		<b>0</b>	<1	---
Magnesium	ppm	ASTM D5185m		<b>0</b>	<1	---
Calcium	ppm	ASTM D5185m		<b>12</b>	22	---
Phosphorus	ppm	ASTM D5185m		<b>425</b>	451	---
Zinc	ppm	ASTM D5185m		<b>6</b>	0	---
Sulfur	ppm	ASTM D5185m		<b>6089</b>	6691	---





CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>5</b>	6	---
Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	0	---
Potassium	ppm	ASTM D5185m	>20	<b>2</b>	<1	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<b>987</b>	4295	---
Particles >6µm		ASTM D7647	>2500	<b>222</b>	1001	---
Particles >14µm		ASTM D7647	>320	<b>25</b>	82	---
Particles >21µm		ASTM D7647	>80	<b>13</b>	21	---
Particles >38µm		ASTM D7647	>20	<b>4</b>	1	---
Particles >71µm		ASTM D7647	>4	<b>3</b>	1	---
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<b>17/15/12</b>	19/17/14	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>1.03</b>	1.11	---




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 142	156	157	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : WC0817277 Received : 06 Nov 2023  
 Lab Number : 05999984 Diagnosed : 13 Nov 2023  
 Unique Number : 10728344 Diagnostician : Angela Borella  
 Test Package : IND 2 ( Additional Tests: PRTCOUNT )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

PIEDMONT NATURAL GAS / DUKE ENERGY  
 680 REV BILL RD  
 MAXTON, NC  
 US 28364

Contact: ANDREW CAVENAUGH  
 andrew.cavenaugh@duke-energy.com

T: (910)227-0302

F: