




PROBLEM SUMMARY

Sample Rating Trend




WATER



Machine Id
015-0068
 Component
6 Swing Drive
 Fluid
SCHAEFFER 267 80W90 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	SEVERE
Water	%	ASTM D6304	>0.2	🔴 8.16	🟡 0.489	🔴 1.46
ppm Water	ppm	ASTM D6304	>2000	🔴 81600	🟡 4890	🔴 14600
Emulsified Water	scalar	*Visual	>0.2	🔴 0.2%	🟡 0.2%	🔴 0.2%

Customer Id: AECCHATN
 Sample No.: WC0868429
 Lab Number: 06000135
 Test Package: CONST



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

19 May 2023 Diag: Sean Felton

WATER



We advise that you check for the source of water entry. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The condition of the oil is acceptable for the time in service.

view report



04 Apr 2022 Diag: Don Baldrige

WATER



We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high concentration of water present in the oil. Free water present. The oil is no longer serviceable due to the presence of contaminants.

view report



06 Apr 2020 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition. All component wear rates are normal. Appearance is milky. There is a high concentration of water present in the oil. High concentration of visible dirt/debris present in the oil. The oil viscosity is higher than normal. Confirm oil type. The oil is no longer serviceable due to the presence of contaminants.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
015-0068

Component
6 Swing Drive

Fluid
SCHAEFFER 267 80W90 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high concentration of water present in the oil.

Fluid Condition

The oil is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0868429	WC0815156	WC0548335
Sample Date	Client Info		01 Nov 2023	19 May 2023	04 Apr 2022
Machine Age	mths	Client Info	0	0	0
Oil Age	mths	Client Info	0	0	0
Oil Changed	Client Info		Not Changed	Not Changed	Not Changed
Sample Status			SEVERE	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >400	81	53	95
Chromium	ppm	ASTM D5185m >10	<1	<1	<1
Nickel	ppm	ASTM D5185m >10	0	<1	0
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m	0	0	2
Aluminum	ppm	ASTM D5185m >25	2	0	<1
Lead	ppm	ASTM D5185m >50	<1	1	1
Copper	ppm	ASTM D5185m >200	2	<1	2
Tin	ppm	ASTM D5185m >10	0	0	<1
Antimony	ppm	ASTM D5185m >5	---	---	---
Vanadium	ppm	ASTM D5185m	0	<1	0
Cadmium	ppm	ASTM D5185m	<1	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	6	13	31
Barium	ppm	ASTM D5185m	4	4	4
Molybdenum	ppm	ASTM D5185m	380	401	411
Manganese	ppm	ASTM D5185m	<1	<1	1
Magnesium	ppm	ASTM D5185m	<1	<1	2
Calcium	ppm	ASTM D5185m	15	15	28
Phosphorus	ppm	ASTM D5185m	731	868	1177
Zinc	ppm	ASTM D5185m	57	21	56
Sulfur	ppm	ASTM D5185m	16883	22134	19446

CONTAMINANTS



	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	8	9	8
Sodium	ppm	ASTM D5185m	<1	<1	1
Potassium	ppm	ASTM D5185m >20	1	2	0
Water	%	ASTM D6304 >0.2	8.16	0.489	1.46
ppm Water	ppm	ASTM D6304 >2000	81600	4890	14600

VISUAL

	method	limit/base	current	history1	history2
White Metal	scalar	*Visual NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual NONE	NONE	NONE	NONE
Silt	scalar	*Visual NONE	NONE	MODER	NONE
Debris	scalar	*Visual NONE	NONE	MODER	VLITE
Sand/Dirt	scalar	*Visual NONE	NONE	NONE	NONE
Appearance	scalar	*Visual NORML	NORML	NORML	NORML
Odor	scalar	*Visual NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual >0.2	0.2%	0.2%	0.2%
Free Water	scalar	*Visual	NEG	NEG	1.0



OIL ANALYSIS REPORT






FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 220	146	146	206

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color				no image	no image	no image
Bottom				no image	no image	no image

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0868429 **Received** : 06 Nov 2023
Lab Number : 06000135 **Diagnosed** : 15 Nov 2023
Unique Number : 10728495 **Diagnostician** : Doug Bogart
Test Package : CONST (Additional Tests: KF)

SHIMMICK CONSTRUCTION
 5535 TRAILHEAD DRIVE
 CHATTANOOGA, TN
 US 37415
 Contact: DANIEL LISELLA
 daniel.lisella@shimmick.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)