




PROBLEM SUMMARY

Sample Rating Trend


ISO

Area
Powerblock
 Machine Id
KAMENGO KAMENGO HPU (S/N PHS01233RER)
 Component
Bulk Fluid Tank
 Fluid
Royal Purple biomass EAL hydraulic oil 46 (--- GAL)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	NORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>5000	▲ 28098	4540	---
Particles >6µm	ASTM D7647	>1300	▲ 11249	972	---
Particles >14µm	ASTM D7647	>160	▲ 1210	90	---
Particles >21µm	ASTM D7647	>40	▲ 346	38	---
Particles >38µm	ASTM D7647	>10	▲ 22	6	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 22/21/17	19/17/14	---

Customer Id: VEOCAR
 Sample No.: WC0814538
 Lab Number: 06000164
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

16 Jun 2023 Diag: Jonathan Hester

NORMAL



This is a baseline read-out on the submitted sample.

view report



21 Mar 2023 Diag: Jonathan Hester

VIS DEBRIS



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



22 Dec 2022 Diag: Jonathan Hester

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
Powerblock
 Machine Id
KAMENGO KAMENGO HPU (S/N PHS01233RER)
 Component
Bulk Fluid Tank
 Fluid
Royal Purple biomass EAL hydraulic oil 46 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0814538	WC0814553	WC0798557
Sample Date	Client Info	01 Nov 2023	16 Jun 2023	21 Mar 2023
Machine Age	mths Client Info	60	26280	26280
Oil Age	mths Client Info	3	26280	26280
Oil Changed	Client Info	Filtered	N/A	N/A
Sample Status		ABNORMAL	NORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m	38	1	2
Chromium	ppm ASTM D5185m	<1	<1	<1
Nickel	ppm ASTM D5185m	0	0	<1
Titanium	ppm ASTM D5185m	1	2	2
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m	0	1	0
Lead	ppm ASTM D5185m	2	2	2
Copper	ppm ASTM D5185m	6	19	35
Tin	ppm ASTM D5185m	<1	2	4
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	0	0
Barium	ppm ASTM D5185m	0	0	0
Molybdenum	ppm ASTM D5185m	0	0	0
Manganese	ppm ASTM D5185m	<1	<1	<1
Magnesium	ppm ASTM D5185m	0	2	3
Calcium	ppm ASTM D5185m	86	105	63
Phosphorus	ppm ASTM D5185m	515	653	520
Zinc	ppm ASTM D5185m	23	18	51
Sulfur	ppm ASTM D5185m	6319	8569	6456

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m	0	<1	0
Sodium	ppm ASTM D5185m	5	<1	1
Potassium	ppm ASTM D5185m >20	2	1	<1

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	▲ 28098	4540	---
Particles >6µm	ASTM D7647 >1300	▲ 11249	972	---
Particles >14µm	ASTM D7647 >160	▲ 1210	90	---
Particles >21µm	ASTM D7647 >40	▲ 346	38	---
Particles >38µm	ASTM D7647 >10	▲ 22	6	---
Particles >71µm	ASTM D7647 >3	2	1	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 22/21/17	19/17/14	---


FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	1.29	1.82	1.94




OIL ANALYSIS REPORT


▲ Particle Trend




Viscosity @ 100°C




Acid Number



Viscosity @ 40°C



Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT ▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	43.31	43.61	43.77
Visc @ 100°C	cSt	ASTM D445	8.04	8.22	---
Viscosity Index (VI)	Scale	ASTM D2270	160	166	---


▲ SAMPLE IMAGES

Color


Bottom

GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0814538 **Received** : 06 Nov 2023
Lab Number : 06000164 **Diagnosed** : 13 Nov 2023
Unique Number : 10728524 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KV100, PrtCount, VI)

VEOLIA ENERGY - FRANKLIN
 3465 HWY 198
 CARNESVILLE, GA
 US 30521
 Contact: DERRICK HARVEY
 derrick.harvey@veolia.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: