

PROBLEM SUMMARY

Sample Rating Trend

ISO

Machine Id


KAESER SFC55 5610216 (S/N 1072)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS											
Sample Status				ABNORMAL	ATTENTION	NORMAL					
Particles >6µm		ASTM D7647	>1300	A 8454	1101	852					
Particles >14µm		ASTM D7647	>80	17 717	<u>▲</u> 127	65					
Particles >21µm		ASTM D7647	>20	148	24	17					
Oil Cleanliness		ISO 4406 (c)	>/17/13	22/20/17	<u> </u>	17/13					
Debris	scalar	*Visual	NONE	▲ MODER	NONE	NONE					

Customer Id: DSSNEW Sample No.: KC124355 Lab Number: 06000503 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

09 Nov 2022 Diag: Angela Borella

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



21 Oct 2021 Diag: Angela Borella

NORMAL



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



28 Oct 2020 Diag: Angela Borella

NORMAL




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT



KAESER SFC55 5610216 (S/N 1072)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Apr2019	Sep2019 Mar2020	Oct2020 Oct2021 Nov2022	Oct2023	
SAMPLE INFORM	NOITAN	method	limit/base	current	history1	history2
Sample Number		Client Info		KC124355	KC85896	KC97630
Sample Date		Client Info		24 Oct 2023	09 Nov 2022	21 Oct 2021
Machine Age	hrs	Client Info		40243	37173	31628
Oil Age	hrs	Client Info		0	6000	5600
Oil Changed		Client Info		N/A	Changed	N/A
Sample Status				ABNORMAL	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	1	1	3
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	15	11	13
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	17	0	0
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus		10TH DE 10E		2	2	13
i ilospilolus	ppm	ASTM D5185m		-	_	13
Zinc	ppm	ASTM D5185m ASTM D5185m		0	0	0
	ppm		limit/base			
Zinc	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m method		o current	0 history1	0 history2
Zinc CONTAMINANTS Silicon	ppm	ASTM D5185m method ASTM D5185m	>25	o current	0 history1 <1	0 history2 0
Zinc CONTAMINANTS Silicon Sodium	ppm ppm ppm	Method ASTM D5185m ASTM D5185m ASTM D5185m	>25 >20	0 current 0 7	0 history1 <1 2	history2 0 0
Zinc CONTAMINANTS Silicon Sodium Potassium	ppm ppm ppm ppm ppm	Method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	>25 >20 >0.05	0 current 0 7 1	0 history1 <1 2 0	0 history2 0 0 0 0
Zinc CONTAMINANTS Silicon Sodium Potassium Water	ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304	>25 >20 >0.05	0 current 0 7 1 0.014	0 history1 <1 2 0 0.006	0 history2 0 0 0 0 0 0 0.007
Zinc CONTAMINANTS Silicon Sodium Potassium Water ppm Water	ppm ppm ppm ppm ppm ppm ppm	Method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304	>25 >20 >0.05 >500	0 current 0 7 1 0.014 145.7	0 history1 <1 2 0 0.006 60.8	0 history2 0 0 0 0 0.007 79.2
Zinc CONTAMINANTS Silicon Sodium Potassium Water ppm Water FLUID CLEANLIN	ppm ppm ppm ppm ppm ppm ppm	Method ASTM D5185m Method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 method	>25 >20 >0.05 >500 limit/base	0 current 0 7 1 0.014 145.7 current	0 history1 <1 2 0 0.006 60.8 history1	0 history2 0 0 0 0 0.007 79.2 history2
Zinc CONTAMINANTS Silicon Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm	ppm ppm ppm ppm ppm ppm ppm	Method ASTM D5185m Method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 Method ASTM D7647	>25 >20 >0.05 >500 limit/base	0 current 0 7 1 0.014 145.7 current 28875	0 history1 <1 2 0 0.006 60.8 history1 4226	0 history2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Zinc CONTAMINANTS Silicon Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm	ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 method ASTM D7647 ASTM D7647	>25 >20 >0.05 >500 limit/base >1300 >80	0 current 0 7 1 0.014 145.7 current 28875 ▲ 8454	0 history1 <1 2 0 0.006 60.8 history1 4226 1101	0 history2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
Zinc CONTAMINANTS Silicon Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm	ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 Method ASTM D7647 ASTM D7647 ASTM D7647	>25 >20 >0.05 >500 limit/base >1300 >80	0 current 0 7 1 0.014 145.7 current 28875 ▲ 8454 ▲ 717	0 history1 <1 2 0 0.006 60.8 history1 4226 1101 ▲ 127	0 history2 0 0 0 0 0.007 79.2 history2 3094 852 65
Zinc CONTAMINANTS Silicon Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm Particles >21µm	ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 ASTM D6304 method ASTM D7647 ASTM D7647 ASTM D7647	>25 >20 >0.05 >500 limit/base >1300 >80 >20 >4	0 current 0 7 1 0.014 145.7 current 28875 ▲ 8454 ▲ 717 ▲ 148	0 history1 <1 2 0 0.006 60.8 history1 4226 1101 ▲ 127 24	0 history2 0 0 0 0 0.007 79.2 history2 3094 852 65 17
Zinc CONTAMINANTS Silicon Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm	ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 ASTM D6304 method ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>25 >20 >0.05 >500 limit/base >1300 >80 >20 >4	0 current 0 7 1 0.014 145.7 current 28875 ▲ 8454	0 history1 <1 2 0 0.006 60.8 history1 4226 1101 ▲ 127 24 2	0 history2 0 0 0 0 0 0.007 79.2 history2 3094 852 65 17
Zinc CONTAMINANTS Silicon Sodium Potassium Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >21µm Particles >38µm Particles >71µm	ppm ppm ppm ppm ppm ppm states	Method ASTM D5185m Method ASTM D5185m ASTM D5185m ASTM D6304 ASTM D6304 Method ASTM D7647	>25 >20 >0.05 >500 limit/base >1300 >80 >20 >4 >3	0 current 0 7 1 0.014 145.7 current 28875 8454 717 148 4 0	0 history1 <1 2 0 0.006 60.8 history1 4226 1101 ▲ 127 24 2 0	0 history2 0 0 0 0 0 0.007 79.2 history2 3094 852 65 17 1



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: KC124355 : 06000503

: 10728863 Test Package : IND 2

: 07 Nov 2023 Received Diagnosed

: 09 Nov 2023 Diagnostician : Jonathan Hester 792 COMMERCE AVE NEW CASTLE, PA US 16101

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: