

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO


KAESER 7126505

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL					
Particles >6µm	ASTM D7647	>1300	<b>4363</b>	528					
Particles >14μm	ASTM D7647	>80	<b>4</b> 370	68					
Particles >21µm	ASTM D7647	>20	<b>93</b>	32					
Oil Cleanliness	ISO 4406 (c)	>17/13	<b>19/16</b>	16/13					

Customer Id: AAIROC Sample No.: KC111706 Lab Number: 06000508 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

# Action Status Date Done By Description Change Fluid --- ? Oil and filter change at the time of sampling has been noted. Change Filter --- ? Oil and filter change at the time of sampling has been noted.

## HISTORICAL DIAGNOSIS

20 Jun 2022 Diag: Jonathan Hester

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





## **OIL ANALYSIS REPORT**

Sample H



ISO



Machine Id

# **KAESER 7126505**

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## DIAGNOSIS

#### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun 2022	0ct2023		
SAMPLE INFORM	AATION	method	limit/base		hiotom/1	hiotom (O
	MATION		iimiybase	current	history1	history2
Sample Number		Client Info		KC111706	KC85859	
Sample Date		Client Info		24 Oct 2023	20 Jun 2022	
Machine Age	hrs	Client Info		15506	9231	
Oil Age	hrs	Client Info		4200	6000	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	23	15	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	2	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	11	30	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		2	4	
Zinc	ppm	ASTM D5185m		0	6	
CONTAMINANTS	1	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	
Sodium	ppm	ASTM D5185m		6	14	
Potassium	ppm	ASTM D5185m	>20	1	3	
Water	%	ASTM D6304	>0.05	0.010	0.029	
ppm Water	ppm	ASTM D6304	>500	109.7	298.6	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		9117	2149	
Particles >6µm		ASTM D7647	>1300	<b>4363</b>	528	
Particles >14µm		ASTM D7647	>80	<b>A</b> 370	68	
Particles >21µm		ASTM D7647	>20	<b>93</b>	32	
Particles >38μm		ASTM D7647	>4	4	5	
Particles >71μm		ASTM D7647	>3	0	1	
Oil Cleanliness		ISO 4406 (c)	>17/13	<b>19/16</b>	16/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.31	0.32	



## **OIL ANALYSIS REPORT**





Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: KC111706 : 06000508 : 10728868

: 07 Nov 2023 Received Diagnosed

: 09 Nov 2023 : Jonathan Hester Diagnostician

499 DELAWARE AVE ROCHESTER, PA US 15074

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: