


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



# Machine Id KAESER ASD30T 2791959 (S/N 1111)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

am2012 Jan2014 Sap2015 Oct2016 Oct2017 Doct2016 Jan2020 Fab2021 Oct2022 Oct202						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC124401	KC111137	KC85876
Sample Date		Client Info		23 Oct 2023	27 Mar 2023	03 Oct 2022
Machine Age	hrs	Client Info		29446	29314	29229
Oil Age	hrs	Client Info		0	2000	1500
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	4	7	8
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	29	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	78	20	21
Calcium	ppm	ASTM D5185m	2	1	0	0
Phosphorus	ppm	ASTM D5185m		2	<1	<1
Zinc	ppm	ASTM D5185m		0	33	30
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		13	8	7
Potassium	ppm	ASTM D5185m	>20	3	<1	3
Water	%	ASTM D6304	>0.05	0.022	0.012	0.009
ppm Water	ppm	ASTM D6304	>500	229.8	124.3	92.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2506	3869	1314
Particles >6µm		ASTM D7647	>1300	792	898	373
Particles >14μm		ASTM D7647	>80	67	47	49
Particles >21µm		ASTM D7647	>20	17	14	13
Particles >38μm		ASTM D7647	>4	2	0	2
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13	19/17/13	18/16/13
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.38	0.33	0.37



## **OIL ANALYSIS REPORT**





Certificate L2367

Sample No. Lab Number **Unique Number** 

Test Package : IND 2

: KC124401 : 06000509

Diagnosed : 10728869

: 07 Nov 2023 Received : 09 Nov 2023 Diagnostician : Jonathan Hester 1100 CRANBERRY WOODS DR CRANBERRY, PA

US 16066

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: