

PROBLEM SUMMARY

Sample Rating Trend

ISO

Machine Id

KAESER BSD 50 4455127 (S/N 1203)


Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

4p-2014 May-2015 May-2016 May-2017 Oct-2018 New-2019 New-2021 No

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	ABNORMAL	NORMAL				
Particles >14μm	ASTM D7647	>80	<u> </u>	189	13				
Particles >21μm	ASTM D7647	>20	28	▲ 36	4				
Oil Cleanliness	ISO 4406 (c)	>/17/13	19/17/14	A 20/19/15	18/15/11				

Customer Id: QPSMAC Sample No.: KC112241 Lab Number: 06000542 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

18 Apr 2023 Diag: Don Baldridge

ISO



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



17 Nov 2022 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



02 Jun 2022 Diag: Don Baldridge

150




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



KAESER BSD 50 4455127 (S/N 1203)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

4x2014 Mm/2015 Mm/2016 Mm/2017 Osa2016 Nov2013 Nov2021 Nov2022 Occ002							
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		KC112241	KC110948	KC103947	
Sample Date		Client Info		13 Oct 2023	18 Apr 2023	17 Nov 2022	
Machine Age	hrs	Client Info		51649	49541	46798	
Oil Age	hrs	Client Info		2107	4723	2280	
Oil Changed		Client Info		Not Changd	Changed	Not Changd	
Sample Status				ATTENTION	ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	0	0	
Lead	ppm	ASTM D5185m	>10	<1	0	0	
Copper	ppm	ASTM D5185m	>50	5	6	4	
Tin	ppm	ASTM D5185m	>10	0	0	0	
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	0	
Magnesium	ppm	ASTM D5185m	90	36	37	42	
Calcium	ppm	ASTM D5185m	2	<1	<1	0	
Phosphorus	ppm	ASTM D5185m		2	3	35	
Zinc	ppm	ASTM D5185m		0	2	20	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	0	0	<1	
Sodium	ppm	ASTM D5185m		14	11	14	
Potassium	ppm	ASTM D5185m	>20	2	0	2	
Water	%	ASTM D6304	>0.05	0.021	0.012	0.021	
ppm Water	ppm	ASTM D6304	>500	217.5	126.8	211.7	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2	
Particles >4μm		ASTM D7647		3018	9962	1475	
Particles >6µm		ASTM D7647	>1300	1126	△ 3045	289	
Particles >14μm		ASTM D7647	>80	<u> </u>	<u> </u>	13	
Particles >21µm		ASTM D7647		<u>^</u> 28	△ 36	4	
Particles >38μm		ASTM D7647	>4	1	2	0	
Particles >71μm		ASTM D7647		0	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	<u>\$\text{\Delta}\$ 20/19/15</u>	18/15/11	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.36	0.36	0.36	



OIL ANALYSIS REPORT



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: