

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO

Machine Id


# KAESER BSD50T 8507783 (S/N 1311)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



## RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS |              |         |                 |             |  |  |  |  |  |
|--------------------------|--------------|---------|-----------------|-------------|--|--|--|--|--|
| Sample Status            |              |         | ABNORMAL        | ABNORMAL    |  |  |  |  |  |
| Particles >6µm           | ASTM D7647   | >1300   | <u> </u>        | 1240        |  |  |  |  |  |
| Particles >14μm          | ASTM D7647   | >80     | <b>1149</b>     | <u></u> 175 |  |  |  |  |  |
| Particles >21µm          | ASTM D7647   | >20     | <u> </u>        | <b>4</b> 3  |  |  |  |  |  |
| Oil Cleanliness          | ISO 4406 (c) | >/17/13 | <b>22/21/17</b> | ▲ 19/17/15  |  |  |  |  |  |

Customer Id: REAROB Sample No.: KC125993 Lab Number: 06000546 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

## **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

## 23 Feb 2023 Diag: Doug Bogart

ISO



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



# KAESER BSD50T 8507783 (S/N 1311)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **DIAGNOSIS**

### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

|                  |          |              | Feb 2023   | 0ct2023         |                 |          |
|------------------|----------|--------------|------------|-----------------|-----------------|----------|
| SAMPLE INFORM    | MATION   | method       | limit/base | current         | history1        | history2 |
| Sample Number    |          | Client Info  |            | KC125993        | KC87541         |          |
| Sample Date      |          | Client Info  |            | 23 Oct 2023     | 23 Feb 2023     |          |
| Machine Age      | hrs      | Client Info  |            | 8044            | 2954            |          |
| Oil Age          | hrs      | Client Info  |            | 0               | 2954            |          |
| Oil Changed      |          | Client Info  |            | N/A             | Changed         |          |
| Sample Status    |          |              |            | ABNORMAL        | ABNORMAL        |          |
| WEAR METALS      |          | method       | limit/base | current         | history1        | history2 |
| Iron             | ppm      | ASTM D5185m  | >50        | 0               | 0               |          |
| Chromium         | ppm      | ASTM D5185m  | >10        | 0               | 0               |          |
| Nickel           | ppm      | ASTM D5185m  | >3         | 1               | 0               |          |
| Titanium         | ppm      | ASTM D5185m  | >3         | 0               | 0               |          |
| Silver           | ppm      | ASTM D5185m  | >2         | 0               | 0               |          |
| Aluminum         | ppm      | ASTM D5185m  | >10        | 0               | <1              |          |
| Lead             | ppm      | ASTM D5185m  | >10        | <1              | 0               |          |
| Copper           | ppm      | ASTM D5185m  | >50        | 17              | 3               |          |
| Tin              | ppm      | ASTM D5185m  | >10        | 0               | 0               |          |
| Vanadium         | ppm      | ASTM D5185m  |            | 0               | <1              |          |
| Cadmium          | ppm      | ASTM D5185m  |            | 0               | 0               |          |
| ADDITIVES        |          | method       | limit/base | current         | history1        | history2 |
| Boron            | ppm      | ASTM D5185m  |            | 0               | 0               |          |
| Barium           | ppm      | ASTM D5185m  | 90         | 0               | 0               |          |
| Molybdenum       | ppm      | ASTM D5185m  |            | 0               | 0               |          |
| Manganese        | ppm      | ASTM D5185m  |            | <1              | 1               |          |
| Magnesium        | ppm      | ASTM D5185m  | 90         | 14              | 49              |          |
| Calcium          | ppm      | ASTM D5185m  | 2          | <1              | 0               |          |
| Phosphorus       | ppm      | ASTM D5185m  |            | 2               | 0               |          |
| Zinc             | ppm      | ASTM D5185m  |            | 0               | 22              |          |
| CONTAMINANTS     | i        | method       | limit/base | current         | history1        | history2 |
| Silicon          | ppm      | ASTM D5185m  | >25        | 0               | <1              |          |
| Sodium           | ppm      | ASTM D5185m  |            | 3               | 11              |          |
| Potassium        | ppm      | ASTM D5185m  | >20        | <1              | 2               |          |
| Water            | %        | ASTM D6304   | >0.05      | 0.012           | 0.014           |          |
| ppm Water        | ppm      | ASTM D6304   | >500       | 129.1           | 144.2           |          |
| FLUID CLEANLIN   | IESS     | method       | limit/base | current         | history1        | history2 |
| Particles >4µm   |          | ASTM D7647   |            | 35787           | 2637            |          |
| Particles >6µm   |          | ASTM D7647   |            | <u> </u>        | 1240            |          |
| Particles >14μm  |          | ASTM D7647   | >80        | <u> 1149</u>    | <u>175</u>      |          |
| Particles >21µm  |          | ASTM D7647   |            | <u>^</u> 92     | <u>43</u>       |          |
| Particles >38µm  |          | ASTM D7647   | >4         | 3               | 3               |          |
| Particles >71µm  |          | ASTM D7647   |            | 0               | 1               |          |
| Oil Cleanliness  |          | ISO 4406 (c) | >/17/13    | <u>22/21/17</u> | <u>19/17/15</u> |          |
| FLUID DEGRADA    | TION     | method       | limit/base | current         | history1        | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045   | 0.4        | 0.36            | 0.38            |          |



## **OIL ANALYSIS REPORT**







Certificate L2367

Lab Number **Unique Number** 

: 06000546 : 10728906 Test Package

: IND 2

Diagnosed : 09 Nov 2023 Diagnostician

: Jonathan Hester

ROBESONIA, PA US 19551 Contact:

T: F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)