


SLICING HALL 5

Vacuum Pump Fluid USPI COMP CLEAN 100 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status				ABNORMAL						
Silicon	ppm	ASTM D5185m	>15	<u> </u>						

Customer Id: SMIKIN Sample No.: USPM31183 Lab Number: 06000571 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u> There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id **SLICING HALL 5** Component

Vacuum Pump Fluic USPI COMP CLEAN 100 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Elemental level of silicon (Si) above normal. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM31183		
Sample Date		Client Info		06 Nov 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0		
Chromium	ppm		>20	0		
Nickel	ppm	ASTM D5185m	>20	1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>20	<1		
Lead	ppm	ASTM D5185m	>20	1		
Copper	ppm	ASTM D5185m		<1		
Tin		ASTM D5185m	>20	<1		
Vanadium	ppm	ASTM D5185m	220	<1		
Cadmium	ppm ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		1		
Phosphorus	ppm	ASTM D5185m		722		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		12		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	4 27		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
Water	%	ASTM D6304	>.1	0.028		
ppm Water	ppm	ASTM D6304	>1000	280.9		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	1775		
Particles >6µm		ASTM D7647	>1300	782		
Particles >14µm		ASTM D7647	>160	91		
Particles >21µm		ASTM D7647	>40	23		
Particles >38µm		ASTM D7647	>10	4		
Particles >71µm		ASTM D7647	>3	1		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	18/17/14		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.052		



Particle Trend

Water (KF)

Viscosity @ 40°C

6

Ē 5

18 31

Ok

6000

5000

3000 Water

2000

100 Π

105

95

90 Ab

8

回台

CSt (40°C

OIL ANALYSIS REPORT

method


limit/base


current


history1

history2

VISUAL







To discuss this sample report, contact Customer Service at 1-800-237-1369.

Vov6/23

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Laboratory

Sample No.

Lab Number

Unique Number

Test Package

Contact/Location: SERVICE MANAGER ? - SMIKIN

T: F:

^{* -} Denotes test methods that are outside of the ISO 17025 scope of accreditation.