


# **OIL ANALYSIS REPORT**

## Sample Rating Trend



NORMAL



# ELLIOTT B5EU2E039-3

Component

Compressor

FSE TURBO COOL 32 (--- GAL)

## DIAGNOSIS

## Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

MPC (Membrane Patch Colorimetry) test indicates acceptable levels of varnish present. There is no indication of any contamination in the oil.

## **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dec202	1 Jun2022	Sep 2022	0ct2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0854943	WC0705881	WC0675235
Sample Date		Client Info		27 Oct 2023	30 Sep 2022	01 Jun 2022
Machine Age	hrs	Client Info		30946	25785	23778
Oil Age	hrs	Client Info		4637	6998	5000
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>25	0	0	0
Lead	ppm	ASTM D5185m	>25	0	0	<1
Copper	ppm	ASTM D5185m	>50	0	0	0
Tin	ppm	ASTM D5185m	>15	0	0	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	<1	<1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		340	396	381
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		102	137	116
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	<1
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.20	0.21	0.24
MDOW	0 1	4 OT) 4 D TO 40	4 =		-	_


MPC Varnish Potential Scale ASTM D7843 >15





## **OIL ANALYSIS REPORT**




## **GRAPHS**













Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: 10728988

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0854943 : 06000628

Received Diagnosed

: 07 Nov 2023 : 14 Nov 2023 Diagnostician : Angela Borella

Test Package : IND 2 ( Additional Tests: MPC )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)


**FS-COMPRESSION CO, LLC** 


203 AERO COURT GREENSBORO, NC

US 27409

Contact: Dallas Burcham dallas.burcham@fs-compression.com

T: (336)605-9622 F: (336)605-9844





Report Id: AIRGREWC [WUSCAR] 06000628 (Generated: 11/14/2023 14:11:39) Rev: 1

This page left intentionally blank