

PROBLEM SUMMARY

Sample Rating Trend

ISO


7336054 (S/N 1155)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status		A	BNORMAL	ABNORMAL	ABNORMAL				
Particles >6µm	ASTM D7647	>1300	13202	△ 3448	<u>▲</u> 6653				
Particles >14μm	ASTM D7647	>80	717	▲ 346	△ 386				
Particles >21µm	ASTM D7647	>20	179	<u></u> 116	<u>\$ 85</u>				
Particles >38μm	ASTM D7647	>4	9	<u> 7</u>	<u> 5</u>				
Oil Cleanliness	ISO 4406 (c)	>/17/13	23/21/17	<u>^</u> 21/19/16	<u>22/20/16</u>				

Customer Id: TUCLEE Sample No.: KC06001064 Lab Number: 06001064 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

22 Nov 2022 Diag: Doug Bogart

WATER



We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



28 Jul 2022 Diag: Jonathan Hester

150



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



23 Jul 2021 Diag: Jonathan Hester

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

7336054 (S/N 1155)

Compressor

KAESER SIGMA (OEM) S-460 (--- LTR)





DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul202	1 Jul2022	Nov2022 0	et2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC06001064	KC104171	KC97509
Sample Date		Client Info		27 Oct 2023	22 Nov 2022	28 Jul 2022
Machine Age	hrs	Client Info		3726	2017	1725
Oil Age	hrs	Client Info		0	292	0
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	1
Lead	ppm	ASTM D5185m	>10	0	<1	<1
Copper	ppm	ASTM D5185m	>50	8	2	4
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	24	64	46
Calcium	ppm	ASTM D5185m	2	0	<1	<1
Phosphorus	ppm	ASTM D5185m		0	8	6
Zinc	ppm	ASTM D5185m		83	24	42
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		14	20	15
Potassium	ppm	ASTM D5185m	>20	7	14	20
Water	%	ASTM D6304	>0.05	0.040	△ 0.051	0.029
ppm Water	ppm	ASTM D6304	>500	408.2	<u></u> 518.9	292.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		57107	10872	35279
Particles >6µm		ASTM D7647	>1300	13202	<u>▲</u> 3448	<u></u> 6653
Particles >14μm		ASTM D7647	>80	<u> </u>	△ 346	▲ 386
Particles >21µm		ASTM D7647	>20	<u> </u>	<u>116</u>	▲ 85
Particles >38μm		ASTM D7647	>4	<u> </u>	<u>^</u> 7	<u> 5</u>
Particles >71µm		ASTM D7647	>3	0	1	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>23/21/17</u>	<u>\$\rightarrow\$ 21/19/16</u>	<u>22/20/16</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.31	0.34	0.28



OIL ANALYSIS REPORT



To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

T: F: