

PROBLEM SUMMARY

Sample Rating Trend

WATER

Machine Id


KAESER BSD 50 7821424 (S/N 1010)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS											
Sample Status				ABNORMAL	NORMAL						
Water	%	ASTM D6304	>0.05	△ 0.360	0.031						
ppm Water	ppm	ASTM D6304	>500	△ 3600	310.7						
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG						

Customer Id: MARCAPMD Sample No.: KCPA007586 Lab Number: 06001076 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

02 Sep 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

WATER

KAESER BSD 50 7821424 (S/N 1010)

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

Contamination

There is a light concentration of water present in the


Fluid Condition

The AN level is acceptable for this fluid.

			Sep 2022	0ct2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA007586	KCP37346	
Sample Date		Client Info		20 Oct 2023	02 Sep 2022	
Machine Age	hrs	Client Info		5152	1978	
Oil Age	hrs	Client Info		0	1978	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	3	2	
Tin	ppm	ASTM D5185m	>10	0	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	39	49	
Calcium	ppm	ASTM D5185m	0	0	<1	
Phosphorus	ppm	ASTM D5185m	0	13	2	
Zinc	ppm	ASTM D5185m	0	210	16	
Sulfur	ppm	ASTM D5185m	23500	18201	20458	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	
Sodium	ppm	ASTM D5185m		6	12	
Potassium	ppm	ASTM D5185m	>20	7	18	
Water	%	ASTM D6304	>0.05	△ 0.360	0.031	
ppm Water	ppm	ASTM D6304	>500	▲ 3600	310.7	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			1185	
Particles >6µm		ASTM D7647	>1300		285	
Particles >14µm		ASTM D7647	>80		5	
Particles >21µm		ASTM D7647	>20		1	
Particles >38µm		ASTM D7647	>4		0	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		17/15/10	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.40	0.41	



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number **Unique Number**

: 06001076 : 10729436

: KCPA007586

Diagnosed Diagnostician : Don Baldridge

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: 07 Nov 2023

: 09 Nov 2023

Received

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

MARYLAND ENVIRONMENTAL SERVICES

1000 RITCHIE RD CAPITAL HEIGHTS, MD US 20743

Contact: Service Manager

rabrown@menv.com

T: F: