




# OIL ANALYSIS REPORT



Machine Id  
**CATERPILLAR GM02**  
 Component  
**Biogas Engine**  
 Fluid  
**MAHLER Q8 Mahler G8 SAE 40 (--- GAL)**

Sample Rating Trend



## DIAGNOSIS

**Recommendation**  
 No corrective action is recommended at this time. Resample at the next service interval to monitor.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 Elemental level of silicon (Si) above normal indicating ingress of seal material.

**Fluid Condition**  
 The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0870536</b>	WC0870545	WC0870499
Sample Date	Client Info		<b>06 Nov 2023</b>	03 Nov 2023	01 Nov 2023
Machine Age	hrs	Client Info	<b>65948</b>	65876	65828
Oil Age	hrs	Client Info	<b>410</b>	338	290
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>45	<b>16</b>	9	7
Chromium	ppm	ASTM D5185m	>2	<b>&lt;1</b>	<1	0
Nickel	ppm	ASTM D5185m	>2	<b>1</b>	<1	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>10	<b>3</b>	2	2
Lead	ppm	ASTM D5185m	>5	<b>&lt;1</b>	<1	0
Copper	ppm	ASTM D5185m	>14	<b>5</b>	1	<1
Tin	ppm	ASTM D5185m	>13	<b>2</b>	2	2
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	<1	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>0</b>	<1	0
Barium	ppm	ASTM D5185m		<b>0</b>	2	0
Molybdenum	ppm	ASTM D5185m		<b>1</b>	1	0
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m		<b>9</b>	7	3
Calcium	ppm	ASTM D5185m		<b>1426</b>	1314	1417
Phosphorus	ppm	ASTM D5185m		<b>367</b>	368	357
Zinc	ppm	ASTM D5185m		<b>440</b>	421	455
Sulfur	ppm	ASTM D5185m		<b>1966</b>	2445	1922

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>200	<b>▲ 220</b>	▲ 210	193
Sodium	ppm	ASTM D5185m		<b>3</b>	0	0
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	2	0

## INFRA-RED





	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>5.6</b>	5.5	5.4
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>16.5</b>	16.2	16.0

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>10.7</b>	10.4	10.3
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.55</b>	0.48	1.025
Base Number (BN)	mg KOH/g	ASTM D2896	8.0	<b>5.70</b>	5.82	5.62











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.2	13.6	13.6

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0870536 **Received** : 07 Nov 2023  
**Lab Number** : 06001121 **Diagnosed** : 09 Nov 2023  
**Unique Number** : 10729481 **Diagnostician** : Sean Felton  
**Test Package** : MOB 2

**OAK GROVE KS**  
 1150 E 700TH AVE  
 ARCADIA, KS  
 US 66711  
 Contact: KALEB WEAVER  
 kaleb.weaver@cubedistrictenergy.com  
 T:  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)