

PROBLEM SUMMARY

Sample Rating Trend

WEAR


KAESER 7902317


Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL				
Aluminum	ppm	ASTM D5185m	>10	<u> </u>	1 3	▲ 42				
Particles >6µm		ASTM D7647	>1300	3230	682	<u>^</u> 2163				
Particles >14µm		ASTM D7647	>80	4 356	13	<u>^</u> 203				
Particles >21µm		ASTM D7647	>20	103	2	<u></u> ▲ 61				
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/19/16	19/17/11	<u>^</u> 20/18/15				

Customer Id: WINRIP Sample No.: KCPA007950 Lab Number: 06001611 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

26 Jul 2023 Diag: Don Baldridge

WEAR



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. The aluminum level has decreased, but is still abnormal. All other component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



02 May 2023 Diag: Angela Borella

WEAR



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



24 Jan 2023 Diag: Doug Bogart

150



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR

KAESER 7902317

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

		0ct2021	Apr2022 Jan2023	3 May2023 Jul2023	0cd2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA007950	KCP54182	KCP53502
Sample Date		Client Info		21 Oct 2023	26 Jul 2023	02 May 2023
Machine Age	hrs	Client Info		19538	17359	15339
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	3	1	3
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<u></u> 14	△ 13	<u>42</u>
Lead	ppm	ASTM D5185m	>10	0	2	0
Copper	ppm	ASTM D5185m	>50	<1	4	<1
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	2
Molybdenum	ppm	ASTM D5185m		0	1	0
Manganese	ppm	ASTM D5185m		0	2	0
Magnesium	ppm	ASTM D5185m		<1	0	<1
Calcium	ppm	ASTM D5185m		<1	0	0
Phosphorus	ppm	ASTM D5185m	500	123	76	299
Zinc	ppm	ASTM D5185m		23	0	66
Sulfur	ppm	ASTM D5185m		1566	1272	1509
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	0
Sodium	ppm	ASTM D5185m		0	5	0
Potassium	ppm	ASTM D5185m	>20	1	3	<1
Water	%	ASTM D6304	>0.05	0.011	0.004	0.005
ppm Water	ppm	ASTM D6304		119.4	43.8	53.0
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		9779	3666	6092
Particles >6µm		ASTM D7647	>1300	4 3230	682	<u>^</u> 2163
Particles >14µm		ASTM D7647	>80	4 356	13	<u>^</u> 203
Particles >21µm		ASTM D7647	>20	103	2	<u></u> 61
Particles >38µm		ASTM D7647	>4	4	0	3
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/16	19/17/11	<u>△</u> 20/18/15
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	0.69	0.78	1.21
•						



OIL ANALYSIS REPORT



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: