


PROBLEM SUMMARY



Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

THOBELIN THO TEOT	LEGGEIG				
Sample Status			ABNORMAL	ABNORMAL	
Particles >6µm	ASTM D7647	>1300	<u> </u>	4 121	
Particles >14µm	ASTM D7647	>80	A 3798	A 306	
Particles >21µm	ASTM D7647	>20	<u> </u>	5 4	
Particles >38µm	ASTM D7647	>4	<u> </u>	2	
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u> </u>	🔺 21/19/15	


Customer Id: FEDWESCA Sample No.: KCPA007885 Lab Number: 06001618 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

27 Jul 2022 Diag: Don Baldridge



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend

ISO

KAESER SK 15 6797767 (S/N 1044)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		-	Jul2022	0ct2023		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA007885	KCP50223	
Sample Date		Client Info		20 Oct 2023	27 Jul 2022	
Machine Age	hrs	Client Info		19816	13347	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	1	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	2	2	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	12	19	
Tin	ppm	ASTM D5185m	>10	0	1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	100	<1	0	
Calcium	ppm	ASTM D5185m	0	<1	0	
Phosphorus	ppm	ASTM D5185m	0	0	5	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	23500	20663	22253	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	5	3	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	<1	0	
Water	%	ASTM D6304	>0.05	0.006	0.005	
ppm Water	ppm	ASTM D6304	>500	65.5	54.3	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		32360	12195	
Particles >6µm		ASTM D7647	>1300	<u> </u>	4 121	
Particles >14µm		ASTM D7647	>80	A 3798	A 306	
Particles >21µm		ASTM D7647	>20	<mark>/</mark> 993	▲ 54	
Particles >38µm		ASTM D7647	>4	<mark>/</mark> 17	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	A 21/19/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.42	0.39	





Built for a lifetime

OIL ANALYSIS REPORT









- e 0.48

0.00

Acid Ni 0.24

:08 Nov 2023

: 09 Nov 2023

Diagnostician : Doug Bogart

Base

Seve

Abnorma

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received

Diagnosed

FEDEX FREIGHT

US 95691

Page 4 of 4

4075 CHANNEL DR

WEST SACRAMENTO, CA

Contact: Service Manager