


PROBLEM SUMMARY

Area
075 G4 [2994724]
Machine Id
B1 Blower
Component
Inboard Bearing
Fluid
SHELL CORENA S4 R46 (--- QTS)

Sample Rating Trend




VISCOSITY




COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



▲ Particle Trend



RECOMMENDATION

Viscosity is mostly returned to stock oil viscosity. Change in viscosity is likely due to incorrect oil application. Contamination is elevated. Filter oil if possible using B6=75 filter media or better. Ensure future oil changes are done with the correct oil. Resample at next normal interval.

PROBLEMATIC TEST RESULTS

| Sample Status | ASTM D7647 | ASTM D7647 | ABNORMAL | ABNORMAL | SEVERE |
|-----------------|--------------|----------------|------------|------------|------------|
| Particles >4µm | >10000 | ▲ 51450 | ▲ 68619 | ▲ 83378 | |
| Particles >6µm | >2500 | ▲ 7946 | ▲ 10277 | ▲ 10531 | |
| Particles >14µm | >160 | ▲ 256 | ▲ 438 | ▲ 706 | |
| Particles >21µm | >40 | ▲ 67 | ▲ 115 | ▲ 190 | |
| Oil Cleanliness | ISO 4406 (c) | >20/18/14 | ▲ 23/20/15 | ▲ 23/21/16 | ▲ 24/21/17 |
| Visc @ 40°C | cSt | ASTM D445 42.3 | ▲ 52.5 | ▲ 86.25 | 47.8 |

Customer Id: HEXGEI
Sample No.: PLS0000678
Lab Number: 06006264
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Mike Johnson +1 (615)771-6030
mike.johnson@amrri.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

VISCOSITY



Viscosity is significantly deviated from previous samples and from the reference ISO 46 oil. Consider flushing and changing oil. Change in viscosity is likely due to incorrect oil application. Wear particles are low and steady. Contamination is elevated. Viscosity is significantly increased, likely due to mixing of stock oils.

view report



WATER



07 Jul 2021 Diag: Mike Johnson

The moisture contaminant level is severely elevated. Please drain, flush and refill the drive. Please chekc the vent port to verify that a high quality dessicant vent filter is in use, and install one if NOT already in use. Please check for other sources of moisture. If the system incorporates the use of a shell and tube oil cooler please pressure check the cooler for air-tight function. The wear rate is low and steady. Aluminum is still very slightly elevated. This may be related to process contaminants. At the given water percentage particle counting information is not reliable. However, the particle counts shows would be considered to be severely elevated. Filtering the oil will help control the particulate at an acceptable level for a blower (20/18/16). At the observed moisture level it is likely that the fluid is chemicall impaired. It would be best to change the oil.

view report



ISO



24 Feb 2021 Diag: Mike Johnson


Continue sampling at regular intervals. Wear debris is low and steady. Aluminum values are higher than normal. The particle count is moderately elevated. Concentrations for particles greater than 38 microns is high. Conditions suggest that fluid is acceptable for continued use.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Area
075 G4 [2994724]

Machine Id
B1 Blower

Component
Inboard Bearing

Fluid
SHELL CORENA S4 R46 (--- QTS)

DIAGNOSIS

Recommendation

Viscosity is mostly returned to stock oil viscosity. Change in viscosity is likely due to incorrect oil application. Contamination is elevated. Filter oil if possible using B6=75 filter media or better. Ensure future oil changes are done with the correct oil. Resample at next normal interval.

Wear

Wear particles are low and steady.

Contamination

Contamination is elevated.

Fluid Condition

Viscosity is slightly increased, likely due to mixing of stock oils.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | PLS0000678 | PLS0000662 | PLS0000322 |
| Sample Date | Client Info | | 03 Nov 2023 | 28 Feb 2023 | 07 Jul 2021 |
| Machine Age | mths | Client Info | 24 | 8 | 0 |
| Oil Age | mths | Client Info | 8 | 8 | 0 |
| Oil Changed | Client Info | | Changed | N/A | N/A |
| Sample Status | | | ABNORMAL | ABNORMAL | SEVERE |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >2 | NEG | NEG | NEG |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|------------|-----------------|--------------|----------|----------|
| PQ | ASTM D8184 | | 12 | 13 | 16 |
| Iron | ppm | ASTM D5185m >20 | <1 | 2 | 4 |
| Chromium | ppm | ASTM D5185m >20 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >20 | 0 | 0 | <1 |
| Titanium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185m >20 | 0 | <1 | 9 |
| Lead | ppm | ASTM D5185m >20 | <1 | <1 | <1 |
| Copper | ppm | ASTM D5185m >20 | 0 | 0 | <1 |
| Tin | ppm | ASTM D5185m >20 | <1 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | --- | --- | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | <1 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | 0 | 0 | 1 |
| Barium | ppm | ASTM D5185m | 0 | <1 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | 0 | 0 | <1 |
| Magnesium | ppm | ASTM D5185m | 0 | <1 | <1 |
| Calcium | ppm | ASTM D5185m | <1 | 0 | <1 |
| Phosphorus | ppm | ASTM D5185m | 128 | 201 | 85 |
| Zinc | ppm | ASTM D5185m | 0 | 6 | 3 |
| Sulfur | ppm | ASTM D5185m | 145 | 122 | 152 |






CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-----------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >15 | <1 | 2 | 0 |
| Sodium | ppm | ASTM D5185m | 0 | <1 | 1 |
| Potassium | ppm | ASTM D5185m >20 | 0 | 0 | 0 |

INFRA-RED

| | method | limit/base | current | history1 | history2 |
|-----------|----------|-------------|------------|----------|----------|
| Soot % | % | *ASTM D7844 | 0 | 0.1 | 0.1 |
| Nitration | Abs/cm | *ASTM D7624 | 4.3 | 4.6 | 5 |
| Sulfation | Abs./1mm | *ASTM D7415 | 8.8 | 9.0 | 8.5 |

OIL ANALYSIS REPORT




| FLUID CLEANLINESS | method | limit/base | current | history1 | history2 |
|-------------------|--------------|------------|------------|------------|------------|
| Particles >4µm | ASTM D7647 | >10000 | ▲ 51450 | ▲ 68619 | ▲ 83378 |
| Particles >6µm | ASTM D7647 | >2500 | ▲ 7946 | ▲ 10277 | ▲ 10531 |
| Particles >14µm | ASTM D7647 | >160 | ▲ 256 | ▲ 438 | ▲ 706 |
| Particles >21µm | ASTM D7647 | >40 | ▲ 67 | ▲ 115 | ▲ 190 |
| Particles >38µm | ASTM D7647 | >10 | 2 | 3 | 5 |
| Particles >71µm | ASTM D7647 | >3 | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >20/18/14 | ▲ 23/20/15 | ▲ 23/21/16 | ▲ 24/21/17 |

| FLUID DEGRADATION | method | limit/base | current | history1 | history2 |
|-------------------|----------------------|------------|---------|----------|----------|
| Oxidation | Abs/.1mm *ASTM D7414 | | 3.1 | 3.4 | 3.2 |
| Acid Number (AN) | mg KOH/g ASTM D8045 | | 0.26 | 0.28 | 0.237 |

| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|----------------|------------|---------|----------|----------|
| White Metal | scalar *Visual | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar *Visual | >2 | NEG | NEG | 0.2% |
| Free Water | scalar *Visual | | NEG | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|---------------|------------|---------|----------|----------|
| Visc @ 40°C | cSt ASTM D445 | 42.3 | ▲ 52.5 | ▲ 86.25 | 47.8 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PLS0000678
Lab Number : 06006264
Unique Number : 10740026
Test Package : IND 2 (Additional Tests: FT-IR, PQ, PrtCount)

HEXION INC - GONZALES PLANT
 4338 HWY 73
 GEISMAR, LA
 US 70734
 Contact: Shannon Ourso
 shannon.ourso@hexion.com;mike.johnson@amrri.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: