

OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



C 2605 C 2605

Component

Reciprocating Compressor

MOBIL PEGASUS 89 (--- GAL)

D 1 /	101	100	0
- 1114	7(-,1/	NOS	-
$ \nu$ $_{1}$ $_{r}$	TOI		\cdot

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

-2016 Apr2019 Nev2019 Jun2020 Dec2020 Nev2021 Aug2022 Jun2023						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		HLC0002592	HLC0001493	HLC0002613
Sample Date		Client Info		04 Nov 2023	03 Oct 2023	05 Sep 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	1	1	<1
Lead	ppm	ASTM D5185m	>25	1	0	0
Copper	ppm	ASTM D5185m	>50	<1	2	2
Tin	ppm	ASTM D5185m	>15	<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		8	8	8
Calcium	ppm	ASTM D5185m		2139	2469	2571
Phosphorus	ppm	ASTM D5185m		203	220	240
Zinc	ppm	ASTM D5185m		214	238	249
Sulfur	ppm	ASTM D5185m		3583	4028	5129
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	7	7	8
Sodium	ppm	ASTM D5185m		0	1	2
Potassium	ppm	ASTM D5185m	>20	0	0	1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		274	206	320
Particles >6µm		ASTM D7647	>2500	93	50	84
Particles >14μm		ASTM D7647	>320	13	3	4
Particles >21μm		ASTM D7647	>80	5	1	1
Particles >38µm		ASTM D7647	>20	0	0	1
Particles >71μm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/18/15	15/14/11	15/13/9	15/14/9
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN) mg KOH/g ASTM D8045


0.722

0.823

0.234



OIL ANALYSIS REPORT



VISUAL		method			history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

3.0-								
E 2.5-							- 1	
2.0							A //	
E 1.3 +							$\Lambda \Pi$	
1.0			- ~/				1111	
1.0	10	~	M	W	V	V	VI	1
3.0 V V V V V V V V V V V V V V V V V V V	Apr23/19	Vov7/19	Jun27/20	Dec23/20	V	V	Jun9/23	1


FLUID PROPEF	RTIES	method				history2
Visc @ 40°C	cSt	ASTM D445	121	118	119	121


Color

SAMPLE IMAGES

Bottom







Non-ferrous Metals Supplemental	
Non-ferrous Metals	
Non-ferrous Metals Non-ferrous Metals Non-ferrous Metals 120 30 8	
Non-ferrous Metals Add 12770 Non Non-ferrous Metals Add 12770 N	
Non-ferrous Metals Subremal	
Viscosity @ 40°C	
Viscosity @ 40°C Acid Number	71
Abnomal 2.00 Base	
Abnormal Base	
Base	. 1
Abnormal	$\Lambda / 1$
123/19 - 123/20 - 123	nn9/23





Laboratory Sample No. Lab Number

: 06006306 Unique Number : 10740068

: HLC0002592 Received : 13 Nov 2023 Diagnosed

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: 15 Nov 2023 Diagnostician : Don Baldridge Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

HILCORP EXPLORATION ALASKA - MILNE POINT

1000 MILNE POINT RD PRUDOE BAY, AK US 99734 Contact: Evan Reilly

evan.reilly@hilcorp.com T: (907)670-3231

F: x: