




PROBLEM SUMMARY

Sample Rating Trend



WATER




Machine Id
KAESER ASD 25 5747171 (S/N 1164)

Component
Compressor


Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Water (KF)



▲ Particle Trend



RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	NORMAL	ATTENTION
Water	%	ASTM D6304	>0.05	▲ 0.077	0.021	0.030
ppm Water	ppm	ASTM D6304	>500	▲ 772.9	219.4	309.4
Particles >6µm		ASTM D7647	>1300	▲ 8955	1041	1133
Particles >14µm		ASTM D7647	>80	▲ 538	71	▲ 130
Particles >21µm		ASTM D7647	>20	▲ 159	17	▲ 35
Particles >38µm		ASTM D7647	>4	▲ 7	1	2
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ 22/20/16	19/17/13	▲ 19/17/14

Customer Id: IMAHIG
 Sample No.: KCPA006476
 Lab Number: 06006335
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

28 Apr 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



09 Dec 2022 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



17 Nov 2021 Diag: Doug Bogart

ISO




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id
KAESER ASD 25 5747171 (S/N 1164)

Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)



DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION method limit/base current history1 history2

Sample Number	Client Info	KCPA006476	KCP53314	KCP55699
Sample Date	Client Info	03 Nov 2023	28 Apr 2023	09 Dec 2022
Machine Age	hrs	Client Info	21036	19540
Oil Age	hrs	Client Info	0	2000
Oil Changed	Client Info	N/A	Not Changd	Changed
Sample Status		ABNORMAL	NORMAL	ATTENTION

WEAR METALS method limit/base current history1 history2

Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	2	2	2
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m		---	---	---
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES method limit/base current history1 history2

Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	3	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	37	67	58
Calcium	ppm	ASTM D5185m	0	2	<1	<1
Phosphorus	ppm	ASTM D5185m	0	1	<1	4
Zinc	ppm	ASTM D5185m	0	30	20	29
Sulfur	ppm	ASTM D5185m	23500	17799	21732	21672

CONTAMINANTS method limit/base current history1 history2

Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		16	17	13
Potassium	ppm	ASTM D5185m	>20	2	4	2
Water	%	ASTM D6304	>0.05	▲ 0.077	0.021	0.030
ppm Water	ppm	ASTM D6304	>500	▲ 772.9	219.4	309.4






FLUID CLEANLINESS method limit/base current history1 history2

Particles >4µm	ASTM D7647			32835	3816	3347
Particles >6µm	ASTM D7647	>1300		▲ 8955	1041	1133
Particles >14µm	ASTM D7647	>80		▲ 538	71	▲ 130
Particles >21µm	ASTM D7647	>20		▲ 159	17	▲ 35
Particles >38µm	ASTM D7647	>4		▲ 7	1	2
Particles >71µm	ASTM D7647	>3		1	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13		▲ 22/20/16	19/17/13	▲ 19/17/14

FLUID DEGRADATION method limit/base current history1 history2

Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.35	0.59	0.41
------------------	----------	------------	-----	-------------	------	------

OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	46.1	48.3	46.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA006476 **Received** : 13 Nov 2023
Lab Number : 06006335 **Diagnosed** : 14 Nov 2023
Unique Number : 10740097 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, PrtCount)

IMAGEFIRST HP
 639 ALTON PL
 HIGH POINT, NC
 US 27263
 Contact: J. SPREADBURY
 jspreadbury@imagefirst.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)