




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
WEST GAS

Component
Compressor

Fluid
MOBIL PEGASUS 805 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USP255339	USP255481	USP246508
Sample Date	Client Info	09 Nov 2023	25 Jul 2023	13 Apr 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	NORMAL	ATTENTION

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	0	<1	0
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	<1	0	0
Aluminum	ppm	ASTM D5185m >25	<1	2	<1
Lead	ppm	ASTM D5185m >25	0	<1	0
Copper	ppm	ASTM D5185m >50	<1	1	<1
Tin	ppm	ASTM D5185m >15	0	<1	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 80	51	100	62
Barium	ppm	ASTM D5185m	0	1	0
Molybdenum	ppm	ASTM D5185m	4	<1	1
Manganese	ppm	ASTM D5185m	0	0	<1
Magnesium	ppm	ASTM D5185m	110	5	7
Calcium	ppm	ASTM D5185m 1020	1428	1446	1459
Phosphorus	ppm	ASTM D5185m 220	395	369	359
Zinc	ppm	ASTM D5185m 230	464	427	408
Sulfur	ppm	ASTM D5185m 1000	2616	2829	2719

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	2	1	2
Sodium	ppm	ASTM D5185m	<1	0	0
Potassium	ppm	ASTM D5185m >20	0	2	0
Water	%	ASTM D6304 >0.1	0.012	0.011	0.005
ppm Water	ppm	ASTM D6304 >1000	122.8	119.4	54.6

FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	5410	2856	▲ 11070
Particles >6µm	ASTM D7647 >2500	716	289	1014
Particles >14µm	ASTM D7647 >320	26	10	18
Particles >21µm	ASTM D7647 >80	7	3	3
Particles >38µm	ASTM D7647 >20	1	0	0
Particles >71µm	ASTM D7647 >4	0	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	20/17/12	19/15/10	▲ 21/17/11

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.761	0.466	0.31




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	130.0	119	125

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP255339 **Received** : 13 Nov 2023
Lab Number : 06006366 **Diagnosed** : 15 Nov 2023
Unique Number : 10740128 **Diagnostician** : Doug Bogart
Test Package : IND 2

ENERGY CENTER DOVER LLC - DCDOV
 1280 W NORTH ST
 DOVER, DE
 US 19904
 Contact: ERNIE JUST
 ernie.just@clearwayenergy.com
 T: (302)678-4353
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)