

PROBLEM SUMMARY

Sample Rating Trend

ISO




KD-2 LIQUID NOX PUMP

Component **Gearbox**

NOT GIVEN (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. Please specify the brand and viscosity of the oil on your next sample.

| PROBLEMATIC TEST RESULTS | | | | | | | | | |
|--------------------------|--------------|-----------|-------------------|--|--|--|--|--|--|
| Sample Status | | | ABNORMAL | | | | | | |
| Particles >4µm | ASTM D7647 | >5000 | 1067 | | | | | | |
| Particles >6µm | ASTM D7647 | >1300 | 18762 | | | | | | |
| Particles >14μm | ASTM D7647 | >160 | 4 955 | | | | | | |
| Particles >21μm | ASTM D7647 | >40 | 278 | | | | | | |
| Particles >38μm | ASTM D7647 | >10 | △ 32 | | | | | | |
| Particles >71μm | ASTM D7647 | >3 | <u>^</u> 6 | | | | | | |
| Oil Cleanliness | ISO 4406 (c) | >19/17/14 | <u>^</u> 23/21/17 | | | | | | |

Customer Id: NRGDOV Sample No.: USP255337 Lab Number: 06006372 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

| RECOMMENDED ACTIONS | | | | | | | |
|----------------------|--------|------|---------|---|--|--|--|
| Action | Status | Date | Done By | Description | | | |
| Change Filter | | | ? | We recommend you service the filters on this component if applicable. | | | |
| Information Required | | | ? | Please specify the brand, type, and viscosity of the oil on your next sample. | | | |

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



KD-2 LIQUID NOX PUMP

Component

Gearbox

NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. Please specify the brand and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| | | | | Nov2023 | | |
|------------------|----------|--------------|---|-------------------|-------------|-----------|
| SAMPLE INFORM | AATIONI | ام معالم مص | 1: ! | | lainta m. 4 | histom (O |
| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | USP255337 | | |
| Sample Date | | Client Info | | 09 Nov 2023 | | |
| Machine Age | hrs | Client Info | | 0 | | |
| Oil Age | hrs | Client Info | | 0 | | |
| Oil Changed | | Client Info | | N/A | | |
| Sample Status | | | | ABNORMAL | | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >200 | 0 | | |
| Chromium | ppm | ASTM D5185m | >15 | 0 | | |
| Nickel | ppm | ASTM D5185m | >15 | 0 | | |
| Titanium | ppm | ASTM D5185m | | 0 | | |
| Silver | ppm | ASTM D5185m | | 0 | | |
| Aluminum | ppm | ASTM D5185m | >25 | 0 | | |
| Lead | ppm | ASTM D5185m | >100 | 0 | | |
| Copper | ppm | ASTM D5185m | >200 | 0 | | |
| Tin | ppm | ASTM D5185m | >25 | 0 | | |
| Vanadium | ppm | ASTM D5185m | | 0 | | |
| Cadmium | ppm | ASTM D5185m | | 0 | | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | | |
| Barium | ppm | ASTM D5185m | | 0 | | |
| Molybdenum | ppm | ASTM D5185m | | 0 | | |
| Manganese | ppm | ASTM D5185m | | 0 | | |
| Magnesium | ppm | ASTM D5185m | | 0 | | |
| Calcium | ppm | ASTM D5185m | | 0 | | |
| Phosphorus | ppm | ASTM D5185m | | 454 | | |
| Zinc | | ASTM D5185m | | 0 | | |
| Sulfur | ppm | ASTM D5185m | | 57 | | |
| | ppm | | limit/bass | | | |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >50 | 18 | | |
| Sodium | ppm | ASTM D5185m | | 0 | | |
| Potassium | ppm | ASTM D5185m | | 0 | | |
| Water | % | ASTM D6304 | | 0.004 | | |
| ppm Water | ppm | ASTM D6304 | >2000 | 44.1 | | |
| FLUID CLEANLIN | IESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | >5000 | <u>^</u> 71067 | | |
| Particles >6μm | | ASTM D7647 | >1300 | <u> </u> | | |
| Particles >14μm | | ASTM D7647 | >160 | <u>^</u> 955 | | |
| Particles >21µm | | ASTM D7647 | >40 | <u>^</u> 278 | | |
| Particles >38μm | | ASTM D7647 | >10 | <u>▲</u> 32 | | |
| Particles >71µm | | ASTM D7647 | >3 | <u>^</u> 6 | | |
| Oil Cleanliness | | ISO 4406 (c) | >19/17/14 | <u>A</u> 23/21/17 | | |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | 0.56 | | |



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: USP255337 : 06006372 : 10740134 Test Package : IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 13 Nov 2023 Received Diagnosed : 14 Nov 2023 Diagnostician : Doug Bogart

ENERGY CENTER DOVER LLC - DCODOV 1280 W NORTH ST

DOVER, DE US 19904

T: (302)678-4353

Contact: ERNIE JUST ernie.just@clearwayenergy.com

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: ERNIE JUST - NRGDOV

F: