




PROBLEM SUMMARY

Sample Rating Trend



WATER



Machine Id

DS2

Component


Hydraulic System

Fluid


HOUGHTON HOUGHTON SAFE 419 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Water (KF)



▲ Particle Trend



RECOMMENDATION

We advise that you replenish the water content and add per manufacturer's recommendations. We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ATTENTION	NORMAL
Water	%	ASTM D6304	>44	▲ 21.0	27.9	34.8
ppm Water	ppm	ASTM D6304		▲ 210000	279000	348000
Particles >6µm		ASTM D7647	>2500	▲ 5028	2047	479
Particles >14µm		ASTM D7647	>320	▲ 856	▲ 348	81
Particles >21µm		ASTM D7647	>80	▲ 288	▲ 117	27
Particles >38µm		ASTM D7647	>20	▲ 45	18	4
Particles >71µm		ASTM D7647	>4	▲ 5	2	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	▲ 20/20/17	▲ 19/18/16	17/16/14

Customer Id: TYSHOP
 Sample No.: USP0003451
 Lab Number: 06006390
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Service/change Fluid	---	---	?	We advise that you replenish the supplemental coolant additives (SCAs) and add per manufacturer's recommendations.
Change Filter	---	---	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

08 Mar 2023 Diag: Doug Bogart

VISCOSITY



We advise that you replenish the water content and add per manufacturer's recommendations. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The water content is lower than normal. The oil viscosity is higher than normal. The pH level of this fluid is within the acceptable limits.

[view report](#)



06 Oct 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The pH level of this fluid is within the acceptable limits at 7.0. The condition of the oil is acceptable for the time in service.

[view report](#)



31 May 2022 Diag: Jonathan Hester

PH



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The pH is low at 6.0. The condition of the oil is acceptable for the time in service.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id

DS2

Component

Hydraulic System

Fluid

HOUGHTON HOUGHTON SAFE 419 (--- GAL)

DIAGNOSIS

▲ Recommendation

We advise that you replenish the water content and add per manufacturer's recommendations. We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The water content is lower than normal. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		USP0003451	USP05787400	USP234548
Sample Date	Client Info		13 Nov 2023	08 Mar 2023	06 Oct 2022
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ATTENTION	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0	<1
Chromium	ppm	ASTM D5185m	>20	0	<1
Nickel	ppm	ASTM D5185m	>20	0	<1
Titanium	ppm	ASTM D5185m		0	0
Silver	ppm	ASTM D5185m		0	0
Aluminum	ppm	ASTM D5185m	>20	0	<1
Lead	ppm	ASTM D5185m	>20	0	<1
Copper	ppm	ASTM D5185m	>20	0	<1
Tin	ppm	ASTM D5185m	>20	0	<1
Vanadium	ppm	ASTM D5185m		0	<1
Cadmium	ppm	ASTM D5185m		0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	2
Barium	ppm	ASTM D5185m		0	0
Molybdenum	ppm	ASTM D5185m		0	0
Manganese	ppm	ASTM D5185m		0	0
Magnesium	ppm	ASTM D5185m		0	<1
Calcium	ppm	ASTM D5185m		0	<1
Phosphorus	ppm	ASTM D5185m		2	6
Zinc	ppm	ASTM D5185m		0	<1
Sulfur	ppm	ASTM D5185m		0	0

CONTAMINANTS


	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	<1
Sodium	ppm	ASTM D5185m		0	4
Potassium	ppm	ASTM D5185m	>20	2	45
Water	%	ASTM D6304	>44	▲ 21.0	27.9
ppm Water	ppm	ASTM D6304		▲ 210000	279000

FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	9230	3758	879
Particles >6µm	ASTM D7647	>2500	▲ 5028	2047	479
Particles >14µm	ASTM D7647	>320	▲ 856	▲ 348	81
Particles >21µm	ASTM D7647	>80	▲ 288	▲ 117	27
Particles >38µm	ASTM D7647	>20	▲ 45	18	4
Particles >71µm	ASTM D7647	>4	▲ 5	2	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 20/20/17	▲ 19/18/16	17/16/14




OIL ANALYSIS REPORT





VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>44	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG







FLUID PROPERTIES	method	limit/base	current	history1	history2
pH	Scale 0-14	ASTM D1287	8.00	7.00	7.00
Visc @ 40°C	cSt	ASTM D445	43.0	56.64	95.89



SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP0003451 **Received** : 13 Nov 2023
Lab Number : 06006390 **Diagnosed** : 16 Nov 2023
Unique Number : 10740152 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: pH, ReserveAlk)

TYSON-HOPE-USP
 HOPE, AR
 US
 Contact: JAMES WEST

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)