

PROBLEM SUMMARY


BATCH 22 BEFORE FILT]

Component


Refrigeration Compressor


RECYCLE NH3 OIL

USPI 1009-68 SC (--- GAL)



COMPONENT CONDITION SUMMARY





RECOMMENDATION

This is a baseline read-out on the submitted sample. BATCH 22 BEFORE FILTRATION

PROBLEMATIC TEST RESULTS											
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL					
Iron	ppm	ASTM D5185m	>8	△ 33	△ 75	<u>^</u> 24					
Particles >6µm		ASTM D7647	>2500	<u> </u>	<u>▲</u> 166218	<u>▲</u> 111353					
Particles >14µm		ASTM D7647	>320	5090	△ 30784	<u>▲</u> 1613					
Particles >21µm		ASTM D7647	>80	<u> </u>	<u>^</u> 2723	46					
Oil Cleanliness		ISO 4406 (c)	>/18/15	25/25/20	<u>\$\text{\scale}\$ 25/25/22</u>	<u>\$\lambda\$</u> 25/24/18					

Customer Id: TYSLEXHID Sample No.: USP249315 Lab Number: 06006406 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

11 Sep 2023 Diag: Doug Bogart

WEAR



This is a baseline read-out on the submitted sample. BATCH 20 BEFOREThe iron level is abnormal. There is a high amount of particulates present in the oil. Viscosity confirmed. The AN level is acceptable for this fluid.



07 Aug 2023 Diag: Doug Bogart

WEAR



This is a baseline read-out on the submitted sample. BATCH 19 BEFORE FILTRATIONThe iron level is abnormal. There is a high amount of particulates present in the oil. Viscosity confirmed. The AN level is acceptable for this fluid.



24 May 2023 Diag: Doug Bogart

WATER



This is a baseline read-out on the submitted sample. BATCH 18 BEFORE FILTRATIONThe iron level is abnormal. There is a high amount of particulates present in the oil. There is a trace of moisture present in the oil. The AN level is acceptable for this fluid.






OIL ANALYSIS REPORT

BATCH 22 BEFORE FILT] **RECYCLE NH3 OIL**

Refrigeration Compressor

USPI 1009-68 SC (--- GAL)





DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample. BATCH 22 BEFORE FILTRATION

The iron level is abnormal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

CAMPLE INCOR	MATION	moyever i	lingit/le a co	22 May2023 Aug2023 Sep202:		hictor
SAMPLE INFORM	/IA HON	method	limit/base		history1	history2
Sample Number		Client Info		USP249315	USP05949247	USP249311
Sample Date		Client Info		10 Nov 2023	11 Sep 2023	07 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	33	<u>^</u> 75	<u>4</u> 24
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>3	0	1	<1
Lead	ppm	ASTM D5185m	>2	0	0	<1
Copper	ppm	ASTM D5185m	>8	0	<1	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		<1	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	0	0	0
CONTAMINANTS		method	limit/base		history1	
)			current		history2
Silicon	ppm	ASTM D5185m	>15	3	5	4
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	0	2	<1
Water	%	ASTM D6304	>0.01	0.007	0.011	0.002
ppm Water	ppm	ASTM D6304	>100	76.9	110.9	21.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		292124	202775	212113
Particles >6µm		ASTM D7647	>2500	<u> </u>	<u>▲</u> 166218	<u>111353</u>
Particles >14μm		ASTM D7647	>320	<u>^</u> 5090	△ 30784	<u></u> 1613
Particles >21μm		ASTM D7647	>80	<u> </u>	<u>▲</u> 2723	46
Particles >38μm		ASTM D7647	>20	0	0	1
Particles >71μm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/18/15	25/25/20	<u>△</u> 25/25/22	2 5/24/18
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.027	0.024	0.014



OIL ANALYSIS REPORT



To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

T: F: