




FUEL REPORT

Sample Rating Trend

NORMAL



Machine Id
WESTCHESTER DEF FORT SLOCUM GEN 1 D030491737

Component
Diesel Fuel
Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0834468	WC0748981	WC0612336
Sample Date	Client Info			09 Oct 2023	28 Oct 2022	07 Dec 2021
Machine Age	hrs	Client Info		120	108	161
Sample Status				NORMAL	NORMAL	NORMAL

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		6	45	0

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	0
Sodium	ppm	ASTM D5185m	<0.1	<1	0	0
Potassium	ppm	ASTM D5185m	<0.1	0	1	0

HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	<1	0
Nickel	ppm	ASTM D5185m	<0.1	0	0	0
Lead	ppm	ASTM D5185m	<0.1	0	0	0
Vanadium	ppm	ASTM D5185m	<0.1	0	0	0
Iron	ppm	ASTM D5185m	<0.1	0	<1	<1
Calcium	ppm	ASTM D5185m	<0.1	1	2	0
Magnesium	ppm	ASTM D5185m	<0.1	0	0	0
Phosphorus	ppm	ASTM D5185m	<0.1	<1	4	0
Zinc	ppm	ASTM D5185m	<0.1	0	1	0

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						





FUEL REPORT

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0834468 **Received** : 13 Nov 2023
Lab Number : 06006634 **Diagnosed** : 16 Nov 2023
Unique Number : 10740396 **Diagnostician** : Jonathan Hester
Test Package : MOB 1

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

GEN TECH LTD
 3017 RT 9W
 NEW WINDSOR, NY
 US 12553

Contact: CHRIS HALVORSEN
 parts@gentechltd.com
 T: (845)568-0500
 F: (845)568-3073