



OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
25KW
 Component
Genset
 Fluid
SAE 30W (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0877667	---	---
Sample Date	Client Info		09 Nov 2023	---	---
Machine Age	hrs	Client Info	6	---	---
Oil Age	hrs	Client Info	6	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			NORMAL	---	---

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	---	---
Glycol	WC Method		NEG	---	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	---
Chromium	ppm	ASTM D5185m	>4	<1	---
Nickel	ppm	ASTM D5185m	>2	0	---
Titanium	ppm	ASTM D5185m		0	---
Silver	ppm	ASTM D5185m	>5	<1	---
Aluminum	ppm	ASTM D5185m	>12	2	---
Lead	ppm	ASTM D5185m	>17	<1	---
Copper	ppm	ASTM D5185m	>70	<1	---
Tin	ppm	ASTM D5185m	>15	0	---
Vanadium	ppm	ASTM D5185m		0	---
Cadmium	ppm	ASTM D5185m		<1	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		121	---
Barium	ppm	ASTM D5185m		7	---
Molybdenum	ppm	ASTM D5185m		256	---
Manganese	ppm	ASTM D5185m		0	---
Magnesium	ppm	ASTM D5185m		461	---
Calcium	ppm	ASTM D5185m		1310	---
Phosphorus	ppm	ASTM D5185m		672	---
Zinc	ppm	ASTM D5185m		782	---
Sulfur	ppm	ASTM D5185m		2322	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	7	---
Sodium	ppm	ASTM D5185m		0	---
Potassium	ppm	ASTM D5185m	>20	2	---

INFRA-RED




	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	---
Nitration	Abs/cm	*ASTM D7624	>20	4.5	---
Sulfation	Abs/.1mm	*ASTM D7415	>30	14.0	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	8.1	---
Base Number (BN)	mg KOH/g	ASTM D2896		6.1	---







OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	MODER	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	11.5	10.4	---

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0877667 **Received** : 14 Nov 2023
Lab Number : 06006737 **Diagnosed** : 16 Nov 2023
Unique Number : 10740499 **Diagnostician** : Sean Felton
Test Package : CONST (Additional Tests: KV40, TBN)

JERRY WATERLAND
 84 WESTBAY DR
 KILMARNOCK, VA
 US 22482

Contact: JERRY WATERLAND
 jerrywaterland@gmail.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: