

OIL ANALYSIS REPORT

Area ULTRA COOLANT [056460] Machine Id INGERSOLL RAND NV8841U10173 - WINCO MFG CO Component

Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend



NORMAL

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06007058		
Sample Date		Client Info		06 Nov 2023		
Machine Age	hrs	Client Info		50946		
Oil Age	hrs	Client Info		1008		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	nnm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	500	787		
	ppm	ASTM D5185m	0	0		
Molybdenum	ppm		0	0		
Manganese	ppm	ASTM D5185m	0	-		
Magnesium	ppm	ASTM D5185m	0	<1 2		
Calcium	ppm		20	2 12		
Phosphorus	ppm	ASTM D5185m				
Zinc Sulfur	ppm	ASTM D5185m ASTM D5185m	0 200	0 258		
	ppm					
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1		
Sodium	ppm	ASTM D5185m		10		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.147		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
5 00 50) B 1			0			

Report Id: UCJOHSAI [WUSCAR] 06007058 (Generated: 11/16/2023 05:22:58) Rev: 1

Contact/Location: RACHEL VON HATTEN - UCJOHSAI



OIL ANALYSIS REPORT



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: RACHEL VON HATTEN - UCJOHSAI

F: (314)874-0965

US 63134

no image

no image