

OIL ANALYSIS REPORT

Sample Rating Trend



herdaza



Area ACAS 115 [6909] Machine Id QUINCY 92789J Component

Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06007083		
Sample Date		Client Info		01 Nov 2023		
Machine Age	hrs	Client Info		85866		
Oil Age	hrs	Client Info		4593		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	1	0		
Barium	ppm	ASTM D5185m	1	0		
Molybdenum	ppm	ASTM D5185m	1	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	1	<1		
Calcium	ppm	ASTM D5185m	1	0		
Phosphorus	ppm	ASTM D5185m	800	409		
Zinc	ppm	ASTM D5185m	20	0		
Sulfur	ppm	ASTM D5185m	37	0		
CONTAMINANTS	\$	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	10		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.24	0.21		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	LIGHT		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
16:11:55) Rev: 1				Contact/Locatio	on: JIM SUARE	Z - UCADVTOM



OIL ANALYSIS REPORT



/23

: UCH06007083

: 06007083

Laboratory Sample No.

Lab Number

Unique Number : 10740845

Test Package : IND 2

Acid Number 0.50 0.45 0.40 (B/HOX Bu) 0.30 1) 0.25 비 0.20 ·B 0.15 0.10 0.05 0.00 Nov1/23 : WearCheck USA - 501 Madison Ave., Cary, NC 27513 ADVANCED COMPRESSED AIR SOLUTIONS (ACAS) Received : 14 Nov 2023 9421 FM 2920 RD BLDG 23 TOMBALL, TX Diagnosed : 16 Nov 2023 Diagnostician : Don Baldridge US 77375 Contact: JIM SUAREZ To discuss this sample report, contact Customer Service at 1-800-237-1369. jim@advancedcompressedair.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: Contact/Location: JIM SUAREZ - UCADVTOM Page 2 of 2

47.8

no image

no image

no image

no image

Certificate L2367