

PROBLEM SUMMARY

Sample Rating Trend


ISO

COLD MILL/CM-5-STAND **MORGOIL 1710-014-1311**

Component Bearing

D-A LUBRICANTS PIB 450 (6000 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC T	EST RESULTS				
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4μm	ASTM D7647	>10000	<u> </u>	<u>149306</u>	<u>▲</u> 132306
Particles >6µm	ASTM D7647	>2500	43646	42200	▲ 30482
Particles >14μm	ASTM D7647	>160	417	<u>▲</u> 757	473
Oil Cleanliness	ISO 4406 (c)	>20/18/14	25/23/16	2 4/23/17	24/22/16

Customer Id: CONMUSAL Sample No.: KFS0004942 Lab Number: 06007656 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

26 May 2023 Diag: Don Baldridge





We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



30 Jan 2023 Diag: Jonathan Hester

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

22 Sep 2022 Diag: Don Baldridge

WEAR



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. The iron level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend


ISO

COLD MILL/CM-5-STAND **MORGOIL 1710-014-1311**

Component

Bearing

D-A LUBRICANTS PIB 450 (6000 GAL)





DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		KFS0004942	KFS0003373	KFS0002522	
Sample Date		Client Info		10 Nov 2023	26 May 2023	30 Jan 2023	
Machine Age	hrs	Client Info		0	0	0	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>20	22	16	13	
Chromium	ppm	ASTM D5185m	>20	0	<1	0	
Nickel	ppm	ASTM D5185m	>20	0	0	0	
Titanium	ppm	ASTM D5185m		0	0	0	
Silver	ppm	ASTM D5185m		0	0	0	
Aluminum	ppm	ASTM D5185m	>20	10	5	8	
Lead	ppm	ASTM D5185m	>20	0	<1	0	
Copper	ppm	ASTM D5185m	>20	<1	<1	<1	
Tin	ppm	ASTM D5185m	>20	2	1	<1	
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	<1	0	
Barium	ppm	ASTM D5185m		0	<1	0	
Molybdenum	ppm	ASTM D5185m		0	<1	<1	
Manganese	ppm	ASTM D5185m		0	<1	<1	
Magnesium	ppm	ASTM D5185m		2	8	3	
Calcium	ppm	ASTM D5185m		13	17	12	
Phosphorus	ppm	ASTM D5185m		20	22	23	
Zinc	ppm	ASTM D5185m		13	20	13	
Sulfur	ppm	ASTM D5185m		164	181	195	
CONTAMINANTS	3	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>15	0	0	<1	
Sodium	ppm	ASTM D5185m		2	<1	<1	
Potassium	ppm	ASTM D5185m	>20	0	<1	0	
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2	
Particles >4μm		ASTM D7647	>10000	160785	▲ 149306	▲ 132306	
Particles >6µm		ASTM D7647	>2500	43646	42200	△ 30482	
		ASTM D7647	>160	<u>417</u>	<u></u> 757	▲ 473	
Particles >14µm		4 O T 1 4 D T 0 4 T	>40	32	<u> 88</u>	4 1	
Particles >14µm Particles >21µm		ASTM D7647	> 10	<u> </u>		_ +1	
Particles >21µm		ASTM D7647 ASTM D7647	>10	0	0	0	
•							
Particles >21μm Particles >38μm		ASTM D7647	>10	0	0	0	
Particles >21µm Particles >38µm Particles >71µm	ATION	ASTM D7647 ASTM D7647	>10 >3	0	0	0	



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No.

Lab Number **Unique Number**

: 10741418

550

500 (2°C)+450

400

350

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 14 Nov 2023 : KFS0004942 Received : 06007656 Diagnosed

: 16 Nov 2023 : Don Baldridge Diagnostician

(mg KOH/g)

0.20

0.00 G

Nov10/23

Test Package : IND 2 (Additional Tests: PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Aug 13/21

CONSTELLIUM

4805 SECOND STREET MUSCLE SHOALS, AL US 35661

Contact: Josh Edwards joshua.edwards@constellium.com

T: (256)386-6613