


PROBLEM SUMMARY

Area HOTLINE/170 REVERSING MILL Machine Id 300 SHEAR MAIN DRIVE 1411-034-6030 Component

Gearbox

CITGO COMPOUND EP 320 (435 GAL)





RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	
Particles >4µm		ASTM D7647	>20000	<u> </u>	4 4559	
Particles >6µm		ASTM D7647	>5000	A 36979	3886	
Oil Cleanliness		ISO 4406 (c)	>21/19/16	<u> </u>	A 23/19/13	
Visc @ 40°C	cSt	ASTM D445	314	<u> </u>	A 274	


Customer Id: CONMUSAL Sample No.: KFS0004930 Lab Number: 06007662 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

12 May 2022 Diag: Jonathan Hester

VISCOSITY



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of silt (particulates < 6 microns in size) present in the oil. The oil viscosity is lower than normal. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Area HOTLINE/170 REVERSING MILL Machine Id 300 SHEAR MAIN DRIVE 1411-034-6030 Component

Gearbox Fluid

CITGO COMPOUND EP 320 (435 GAL)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 6 microns in size) present in the oil.

Fluid Condition


The oil viscosity is lower than normal. The AN level is acceptable for this fluid.



SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KFS0004930	KFS0001305	
Sample Date		Client Info		10 Nov 2023	12 May 2022	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	19	4	
Chromium	ppm	ASTM D5185m	>15	0	0	
Nickel	ppm	ASTM D5185m	>15	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	0	<1	
Lead	ppm	ASTM D5185m	>100	12	1	
Copper	ppm	ASTM D5185m	>200	0	<1	
Tin	ppm	ASTM D5185m	>25	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	3	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		0	<1	
Calcium	ppm	ASTM D5185m		<1	0	
Phosphorus	ppm	ASTM D5185m		114	93	
Zinc	ppm	ASTM D5185m		2	0	
Sulfur	ppm	ASTM D5185m		4992	5808	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<1	<1	
Sodium	ppm	ASTM D5185m		<1	0	
Potassium	ppm	ASTM D5185m	>20	0	<1	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	🔺 155110	4 4559	
Particles >6µm		ASTM D7647	>5000	<u> </u>	3886	
Particles >14µm		ASTM D7647	>640	297	66	
Particles >21µm		ASTM D7647	>160	30	13	
Particles >38µm		ASTM D7647	>40	1	0	
Particles >71µm		ASTM D7647	>10	0	0	
Oil Cleanliness		ISO 4406 (c)	>21/19/16	4/22/15	2 3/19/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.31	0.18	



OIL ANALYSIS REPORT





14

Acid Number

Vav1

: 14 Nov 2023

: 16 Nov 2023

214

38

history1

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

history

NEG

NEG

274

current

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

curren

NEG

NEG

history2

historv2

4406

:1999 Cle

14



: Don Baldridge Unique Number : 10741424 Diagnostician Test Package : IND 2 (Additional Tests: PrtCount) Certificate L2367 joel.even@constellium.com To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: KFS0004930

: 06007662

Received

Diagnosed

Report Id: CONMUSAL [WUSCAR] 06007662 (Generated: 11/17/2023 15:08:26) Rev: 1

Sample No.

Lab Number

Submitted By: Kenneth Humphries

Page 4 of 4

CONSTELLIUM

US 35661

F:

4805 SECOND STREET

MUSCLE SHOALS, AL

Contact: Joel Even

T: (256)740-7490