




PROBLEM SUMMARY

Sample Rating Trend




ISO



Area
HOTLINE/120 MILL
 Machine Id
120 SCREWDOWN LUBE RESV 1415-014-0160
 Component
Gearbox
 Fluid
CITGO COMPOUND EP 320 (3000 GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>20000	▲ 168165	▲ 234626	▲ 278340
Particles >6µm	ASTM D7647	>5000	▲ 69647	▲ 151999	▲ 179872
Particles >14µm	ASTM D7647	>640	▲ 2371	▲ 9491	▲ 10883
Particles >21µm	ASTM D7647	>160	▲ 280	▲ 964	▲ 1124
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 25/23/18	▲ 25/24/20	▲ 25/25/21

Customer Id: CONMUSAL
 Sample No.: KFS0004923
 Lab Number: 06007665
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

19 Jul 2023 Diag: Angela Borella

WEAR



Check seals and/or filters for points of contaminant entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

[view report](#)



23 Jun 2023 Diag: Angela Borella

WEAR



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

[view report](#)



27 Mar 2023 Diag: Don Baldrige

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count. All component wear rates are normal. Appearance is milky. There is a high concentration of water present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
HOTLINE/120 MILL
 Machine Id
120 SCREWDOWN LUBE RESV 1415-014-0160
 Component
Gearbox
 Fluid
CITGO COMPOUND EP 320 (3000 GAL)

DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KFS0004923	KFS0003799	KFS0003861
Sample Date	Client Info	10 Nov 2023	19 Jul 2023	23 Jun 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >200	12	41	50
Chromium	ppm ASTM D5185m >15	0	<1	<1
Nickel	ppm ASTM D5185m >15	0	<1	<1
Titanium	ppm ASTM D5185m	0	0	0
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m >25	7	▲ 30	▲ 37
Lead	ppm ASTM D5185m >100	3	2	2
Copper	ppm ASTM D5185m >200	<1	7	8
Tin	ppm ASTM D5185m >25	0	<1	<1
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	<1	31	37
Barium	ppm ASTM D5185m	0	2	0
Molybdenum	ppm ASTM D5185m	0	0	0
Manganese	ppm ASTM D5185m	0	<1	1
Magnesium	ppm ASTM D5185m	3	6	4
Calcium	ppm ASTM D5185m	33	598	707
Phosphorus	ppm ASTM D5185m	129	108	111
Zinc	ppm ASTM D5185m	12	4	0
Sulfur	ppm ASTM D5185m	5288	4887	7204

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	<1	2	<1
Sodium	ppm ASTM D5185m	1	6	6
Potassium	ppm ASTM D5185m >20	2	3	4


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	▲ 168165	▲ 234626	▲ 278340
Particles >6µm	ASTM D7647 >5000	▲ 69647	▲ 151999	▲ 179872
Particles >14µm	ASTM D7647 >640	▲ 2371	▲ 9491	▲ 10883
Particles >21µm	ASTM D7647 >160	▲ 280	▲ 964	▲ 1124
Particles >38µm	ASTM D7647 >40	4	8	4
Particles >71µm	ASTM D7647 >10	0	2	0
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 25/23/18	▲ 25/24/20	▲ 25/25/21


FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	0.31	0.27	0.27


▲ Particle Trend




▲ Particle Trend



Acid Number




Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 314	374	376	▲ 406

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KFS0004923 **Received** : 14 Nov 2023
Lab Number : 06007665 **Diagnosed** : 04 Dec 2023
Unique Number : 10741427 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: PrtCount)

CONSTELLIUM
 4805 SECOND STREET
 MUSCLE SHOALS, AL
 US 35661
 Contact: Joel Even
 joel.even@constellium.com
 T: (256)740-7490
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)