




# PROBLEM SUMMARY

Sample Rating Trend





**WATER**



Area  
**HOTLINE/120 MILL**  
 Machine Id  
**#2 PINCH ROLL REDUCER TOP 1415-004-0080 TOP**  
 Component  
**Top Gearbox**  
 Fluid  
**CITGO COMPOUND EP 320 (12 GAL)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you check for the source of water entry. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	ABNORMAL	---
Water	%	ASTM D6304	>0.2	▲ <b>0.852</b>	---	---
ppm Water	ppm	ASTM D6304	>2000	▲ <b>8520</b>	---	---
Emulsified Water	scalar	*Visual	>0.2	▲ <b>0.2%</b>	NEG	---
Visc @ 40°C	cSt	ASTM D445	314	▲ <b>446</b>	▲ 416.9	---

Customer Id: CONMUSAL  
 Sample No.: KFS0004815  
 Lab Number: 06007672  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

## HISTORICAL DIAGNOSIS

**31 May 2023 Diag: Jonathan Hester**

### VISCOSITY



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Viscosity of sample indicates oil is within ISO 460 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.


view report





# OIL ANALYSIS REPORT

## Sample Rating Trend



**WATER**



Area  
**HOTLINE/120 MILL**  
 Machine Id  
**#2 PINCH ROLL REDUCER TOP 1415-004-0080 TOP**  
 Component  
**Top Gearbox**  
 Fluid  
**CITGO COMPOUND EP 320 (12 GAL)**

### DIAGNOSIS

#### Recommendation

We advise that you check for the source of water entry. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate concentration of water present in the oil.

#### Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KFS0004815</b>	KFS0003345	---
Sample Date	Client Info	<b>10 Nov 2023</b>	31 May 2023	---
Machine Age	hrs	Client Info	<b>0</b>	0
Oil Age	hrs	Client Info	<b>0</b>	0
Oil Changed	Client Info	<b>N/A</b>	N/A	---
Sample Status		<b>ABNORMAL</b>	ABNORMAL	---

### WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	<b>19</b>	120
Chromium	ppm	ASTM D5185m >15	<b>0</b>	0
Nickel	ppm	ASTM D5185m >15	<b>0</b>	0
Titanium	ppm	ASTM D5185m	<b>0</b>	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0
Aluminum	ppm	ASTM D5185m >25	<b>1</b>	4
Lead	ppm	ASTM D5185m >100	<b>0</b>	0
Copper	ppm	ASTM D5185m >200	<b>6</b>	<1
Tin	ppm	ASTM D5185m >25	<b>0</b>	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0

### ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	<1
Barium	ppm	ASTM D5185m	<b>0</b>	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	1
Magnesium	ppm	ASTM D5185m	<b>2</b>	0
Calcium	ppm	ASTM D5185m	<b>7</b>	4
Phosphorus	ppm	ASTM D5185m	<b>115</b>	106
Zinc	ppm	ASTM D5185m	<b>9</b>	0
Sulfur	ppm	ASTM D5185m	<b>5237</b>	8280

### CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>2</b>	2
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	6
Potassium	ppm	ASTM D5185m >20	<b>2</b>	<1
Water	%	ASTM D6304 >0.2	<b>▲ 0.852</b>	---
ppm Water	ppm	ASTM D6304 >2000	<b>▲ 8520</b>	---




### FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	---	<b>▲ 241683</b>	---
Particles >6µm	ASTM D7647 >5000	---	<b>▲ 48959</b>	---
Particles >14µm	ASTM D7647 >640	---	371	---
Particles >21µm	ASTM D7647 >160	---	94	---
Particles >38µm	ASTM D7647 >40	---	12	---
Particles >71µm	ASTM D7647 >10	---	2	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	---	<b>▲ 25/23/16</b>	---

### FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.38</b>	0.25

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	▲ 0.2%	NEG
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 314	▲ 446	▲ 416.9	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color			no image
Bottom			no image

### GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KFS0004815 **Received** : 14 Nov 2023  
**Lab Number** : 06007672 **Diagnosed** : 16 Nov 2023  
**Unique Number** : 10741434 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**CONSTELLIUM**  
 4805 SECOND STREET  
 MUSCLE SHOALS, AL  
 US 35661  
 Contact: Joel Even  
 joel.even@constellium.com  
 T: (256)740-7490  
 F: