




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
METRO
 Machine Id
METRO 21036
 Component
Rear Differential
 Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0843125	WC0765884	WC0661184
Sample Date	Client Info		02 Nov 2023	11 Oct 2022	30 Dec 2021
Machine Age	mls	Client Info	258361	177858	118342
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	234	173	149
Chromium	ppm	ASTM D5185m >10	1	2	1
Nickel	ppm	ASTM D5185m >10	<1	1	0
Titanium	ppm	ASTM D5185m	0	<1	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	4	4	3
Lead	ppm	ASTM D5185m >25	0	<1	0
Copper	ppm	ASTM D5185m >100	<1	1	<1
Tin	ppm	ASTM D5185m >10	0	<1	0
Antimony	ppm	ASTM D5185m >5	---	---	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	116	120	128
Barium	ppm	ASTM D5185m	<1	<1	2
Molybdenum	ppm	ASTM D5185m	0	<1	<1
Manganese	ppm	ASTM D5185m	4	4	3
Magnesium	ppm	ASTM D5185m	147	148	145
Calcium	ppm	ASTM D5185m	8	8	8
Phosphorus	ppm	ASTM D5185m	1737	1639	1676
Zinc	ppm	ASTM D5185m	11	10	7
Sulfur	ppm	ASTM D5185m	22870	25056	21244

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >75	50	42	30
Sodium	ppm	ASTM D5185m	8	8	5
Potassium	ppm	ASTM D5185m >20	1	<1	0
Water	%	ASTM D6304 >.2	0.030	0.044	0.026
ppm Water	ppm	ASTM D6304 >2000	302.2	441.5	263.2

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 79653	▲ 82964	---
Particles >6µm	ASTM D7647	>5000	▲ 6728	4525	---
Particles >14µm	ASTM D7647	>640	45	33	---
Particles >21µm	ASTM D7647	>160	13	5	---
Particles >38µm	ASTM D7647	>40	1	1	---
Particles >71µm	ASTM D7647	>10	1	1	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 23/20/13	▲ 24/19/12	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.23	1.10	1.37




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	48.3	49.3	51.0
Visc @ 100°C	cSt	ASTM D445	9	9.2	9.5
Viscosity Index (VI)	Scale	ASTM D2270	169	171	173

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0843125 **Received** : 14 Nov 2023
Lab Number : 06007680 **Diagnosed** : 16 Nov 2023
Unique Number : 10741442 **Diagnostician** : Don Baldrige
Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCount, VI)

BASF - GIANNA CREDAROLI
 500 WHITE PLAINS RD
 TARRYTOWN, NY
 US 10591
 Contact: GIANNA CREDAROLI
 gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)