




PROBLEM SUMMARY

Sample Rating Trend




WATER



Machine Id
KAESER AS-25 5413891 (S/N 1174)
 Component
Compressor
 Fluid
SYNTHETIC (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Water (KF)



RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

| Sample Status | | | | ABNORMAL | ABNORMAL | ABNORMAL |
|---------------|--------|------------|-------|-----------------|----------|----------|
| Water | % | ASTM D6304 | >0.05 | ▲ 0.204 | ▲ 0.150 | ▲ 0.374 |
| ppm Water | ppm | ASTM D6304 | >500 | ▲ 2040 | ▲ 1500 | ▲ 3740 |
| Silt | scalar | *Visual | NONE | ▲ HEAVY | NONE | ▲ HEAVY |
| Appearance | scalar | *Visual | NORML | ▲ HAZY | NORML | ▲ HAZY |

Customer Id: WATPATKC
 Sample No.: KC125895
 Lab Number: 06007725
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|--------|--------|------|---------|---|
| Alert | --- | --- | ? | We were unable to perform a particle count due to a high concentration of particles present in this sample. |

HISTORICAL DIAGNOSIS

25 Nov 2022 Diag: Don Baldrige

WATER



The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



12 Nov 2021 Diag: Jonathan Hester

WATER



We advise that you stop the unit and follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Appearance is hazy. There is a moderate concentration of water present in the oil. There is a high amount of visible silt present in the sample. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



06 Nov 2020 Diag: Angela Borella

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id
KAESER AS-25 5413891 (S/N 1174)

Component
Compressor
Fluid
SYNTHETIC (--- GAL)



DIAGNOSIS

▲ Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

▲ Contamination

Appearance is hazy. There is a moderate concentration of water present in the oil. There is a high amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | KC125895 | KC95061 | KC73421 |
| Sample Date | Client Info | | | 06 Nov 2023 | 25 Nov 2022 | 12 Nov 2021 |
| Machine Age | hrs | Client Info | | 16837 | 15839 | 14721 |
| Oil Age | hrs | Client Info | | 5683 | 4685 | 3567 |
| Oil Changed | Client Info | | | Not Chngd | Not Chngd | Not Chngd |
| Sample Status | | | | ABNORMAL | ABNORMAL | ABNORMAL |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m | >50 | 0 | <1 | 0 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | <1 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Lead | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m | >50 | 22 | 15 | 8 |
| Tin | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | | --- | --- | 0 |
| Vanadium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |




| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|----------|----------|----------|
| Boron | ppm | ASTM D5185m | | 0 | 0 | <1 |
| Barium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m | | 0 | 7 | 20 |
| Calcium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | | 0 | 33 | 0 |
| Zinc | ppm | ASTM D5185m | | 0 | 30 | 14 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|----------------|----------|----------|
| Silicon | ppm | ASTM D5185m | >25 | 0 | 2 | 0 |
| Sodium | ppm | ASTM D5185m | | 2 | 3 | 8 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 0 | 1 |
| Water | % | ASTM D6304 | >0.05 | ▲ 0.204 | ▲ 0.150 | ▲ 0.374 |
| ppm Water | ppm | ASTM D6304 | >500 | ▲ 2040 | ▲ 1500 | ▲ 3740 |

| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
|-------------------|--|--------------|------------|------------|----------|----------|
| Particles >4µm | | ASTM D7647 | | --- | --- | --- |
| Particles >6µm | | ASTM D7647 | >1300 | --- | --- | --- |
| Particles >14µm | | ASTM D7647 | >80 | --- | --- | --- |
| Particles >21µm | | ASTM D7647 | >20 | --- | --- | --- |
| Particles >38µm | | ASTM D7647 | >4 | --- | --- | --- |
| Particles >71µm | | ASTM D7647 | >3 | --- | --- | --- |
| Oil Cleanliness | | ISO 4406 (c) | >--/17/13 | --- | --- | --- |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | 0.29 | 0.31 | 0.331 |


OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | ▲ HEAVY | NONE |
| Debris | scalar | *Visual | NONE | NONE | ▲ MODER |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | ▲ HAZY | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | 0.2% | ▲ 0.2% |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|-------------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 43.9 | 44.0 | 44.3 |

SAMPLE IMAGES



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC125895 **Received** : 14 Nov 2023
Lab Number : 06007725 **Diagnosed** : 06 Dec 2023
Unique Number : 10741487 **Diagnostician** : Doug Bogart
Test Package : IND 2

WATCHTOWER
 2891 ROUTE 22
 PATTERSON, NY
 US 12563
 Contact: TONY ALVAREZ
 aalvarez3516@gmail.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: