

# **PROBLEM SUMMARY**


Sample Rating Trend

ISO

# Machine Id KAESER SK 15 4026809 (S/N 1027)


Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)





## **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL	NORMAL				
Particles >6µm	ASTM D7647	>1300	<b>4304</b>	209	661				
Particles >14µm	ASTM D7647	>80	<u> </u>	13	38				
Particles >21µm	ASTM D7647	>20	<b>△</b> 37	4	9				
Oil Cleanliness	ISO 4406 (c)	>17/13	<b>19/15</b>	15/11	17/12				

Customer Id: STILON Sample No.: KCPA006876 Lab Number: 06008323 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

## **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

#### HISTORICAL DIAGNOSIS

#### 06 Apr 2023 Diag: Angela Borella

#### NORMAL



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 07 Oct 2022 Diag: Angela Borella

#### NORMAL



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 30 Jul 2021 Diag: Don Baldridge

#### NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER SK 15 4026809 (S/N 1027)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

## DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jun2013 Nov	2016 Oct2018 Dec2019	Dec2020 Jul2021 Oct2022 Apr202	3 Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006876	KCP53591	KCP50482
Sample Date		Client Info		07 Nov 2023	06 Apr 2023	07 Oct 2022
Machine Age	hrs	Client Info		30674	27395	24878
Oil Age	hrs	Client Info		0	3000	2721
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	1	<1	2
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	72	55	39
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	100	90	93	55
Calcium	ppm	ASTM D5185m	0	<1	0	2
Phosphorus	ppm	ASTM D5185m	0	0	0	10
Zinc	ppm	ASTM D5185m	0	1	0	10
Sulfur	ppm	ASTM D5185m	23500	20555	22891	22410
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		7	14	13
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.05	0.011	0.012	0.003
ppm Water	ppm	ASTM D6304	>500	117.6	129.4	25.7
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		17931	857	2889
Particles >6µm		ASTM D7647	>1300	<b>4304</b>	209	661
Particles >14µm		ASTM D7647	>80	<b>199</b>	13	38
Particles >21µm		ASTM D7647	>20	<u>▲</u> 37	4	9
Particles >38µm		ASTM D7647	>4	1	1	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>17/13	<u> </u>	15/11	17/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
	1/011/	10T11 D0015	4.0			0 = 4

mg KOH/g ASTM D8045 1.0

Acid Number (AN)

0.33

0.51



## **OIL ANALYSIS REPORT**



To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: