

## **PROBLEM SUMMARY**

Sample Rating Trend


**WATER** 


# **S MARLEN LEYBOLD SV200 (S/N U141100116)**


**Vacuum Pump** 


**USPI VAC 100 (--- GAL)** 

### **COMPONENT CONDITION SUMMARY**









### RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL			
Phosphorus	ppm	ASTM D5185m	1800	<u></u> 65			
Zinc	ppm	ASTM D5185m	0	<b>48</b>			
Sulfur	ppm	ASTM D5185m	0	<b>1336</b>			
Water	%	ASTM D6304	>.1	<b>△</b> 0.712			
ppm Water	ppm	ASTM D6304	>1000	<u> </u>			
Particles >4µm		ASTM D7647	>5000	<b>36865</b>			
Particles >6µm		ASTM D7647	>1300	<b>△</b> 6395			
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u>22/20/14</u>			
Appearance	scalar	*Visual	NORML	▲ HAZY			
<b>Emulsified Water</b>	scalar	*Visual	>.1	<b>0.2%</b>			
Visc @ 40°C	cSt	ASTM D445	91	<b>83.8</b>			

Customer Id: TYSKAN Sample No.: USPM31288 Lab Number: 06008346 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS				
Action	Status	Date	Done By	Description
Change Filter			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Filter Fluid			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS



### **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

## **S MARLEN LEYBOLD SV200 (S/N U141100116)**

Component

**Vacuum Pump** 

USPI VAC 100 (--- GAL)

DIAGNOSIS

### Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. Appearance is hazy. There is a moderate concentration of water present in the oil.

### ▲ Fluid Condition

The oil viscosity is lower than normal. This plus the additive levels indicates the addition of a different brand, or type of oil. Confirmed. The AN level is acceptable for this fluid.

		Ī				
				Nov2023		
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM31288		
Sample Date		Client Info		10 Nov 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>20	7		
Chromium	ppm	ASTM D5185m	>20	0		
Nickel	ppm	ASTM D5185m	>20	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>20	8		
_ead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>20	<1		
Tin	ppm	ASTM D5185m	>20	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	0	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		<1		
//agnesium	ppm	ASTM D5185m	0	0		
Calcium	ppm	ASTM D5185m	0	<1		
Phosphorus	ppm	ASTM D5185m	1800	<b>△</b> 65		
Zinc	ppm	ASTM D5185m	0	<u> 48</u>		
Sulfur	ppm	ASTM D5185m	0	<u>▲</u> 1336		
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	3		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
Water	%	ASTM D6304	>.1	<b>△</b> 0.712		
opm Water	ppm	ASTM D6304	>1000	<u></u> 7017		
FLUID CLEANLII	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	▲ 36865		
Particles >6µm		ASTM D7647	>1300	<b>△</b> 6395		
Particles >14μm		ASTM D7647	>160	93		
Particles >21µm		ASTM D7647	>40	11		
Particles >38µm		ASTM D7647	>10	4		
Particles >71µm		ASTM D7647	>3	1		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<b>22/20/14</b>		
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2


Acid Number (AN)

mg KOH/g ASTM D8045 0.05

0.17



## **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number Unique Number Test Package : IND 2

: USPM31288 : 06008346

Received Diagnosed : 10742108

: 21 Nov 2023 Diagnostician : Doug Bogart

4612 SPEAKER RD KANSAS CITY, KS US 66105

Contact: WILLIAM KENNEDY

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: