

PROBLEM SUMMARY

Sample Rating Trend




GEA-3 (S/N S2078)

Refrigeration Compressor

USPI 1009-68 SC (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status		ABNORM#	AL ABNORMAL	ABNORMAL					
Particles >4µm	ASTM D7647 >10	000 4 91447	<u>42309</u>	<u></u> 54688					
Particles >6µm	ASTM D7647 >25	00 A 32434	▲ 13317	<u> </u>					
Particles >14μm	ASTM D7647 >32	0 🛕 1051	484	<u></u> 884					
Particles >21µm	ASTM D7647 >80	<u> </u>	4 90	<u> </u>					
Oil Cleanliness	ISO 4406 (c) >20	/18/15 24/22/17	23/21/16	<u>△</u> 23/21/17					

Customer Id: SMILIN Sample No.: USP0003710 Lab Number: 06008392 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

29 Jul 2023 Diag: Doug Bogart





We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



08 Mar 2023 Diag: Doug Bogart

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



09 Jun 2022 Diag: Doug Bogart

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



GEA-3 (S/N S2078)

Refrigeration Compressor

USPI 1009-68 SC (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep2021	Dec2021 Jun2022	Mar2023 Jul2023	0ct2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0003710	USP0000651	USP249060
Sample Date		Client Info		18 Oct 2023	29 Jul 2023	08 Mar 2023
Machine Age	hrs	Client Info		55217	54365	52626
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	<1	2
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	<1	<1
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	<1	<1	<1
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	<1	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	<1	0
Phosphorus	ppm	ASTM D5185m		0	0	<1
Zinc	ppm	ASTM D5185m		2	0	1
Sulfur	ppm	ASTM D5185m	50	10	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	7	2
Sodium	ppm	ASTM D5185m		<1	1	0
Potassium	ppm	ASTM D5185m	>20	<1	<1	<1
Water	%	ASTM D6304	>0.01	0.003	0.003	0.004
ppm Water	ppm	ASTM D6304	>100	29.8	34.2	45.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<u> </u>	42309	<u>▲</u> 54688
Particles >6µm		ASTM D7647	>2500	^ 32434	<u>▲</u> 13317	<u>▲</u> 16176
Particles >14μm		ASTM D7647	>320	<u> </u>	484	<u></u> 884
Particles >21µm		ASTM D7647	>80	<u> </u>	4 90	<u>▲</u> 165
Particles >38µm		ASTM D7647	>20	1	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u> </u>	<u>\$\rightarrow\$ 23/21/16</u>	<u>\$\text{\scale}\$ 23/21/17</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.014	0.014	0.015



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

Test Package

: 06008392

: IND 2

: USP0003710 : 10742154

Diagnosed Diagnostician

: 21 Nov 2023 : Doug Bogart LINCOLN, NE US 68508

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: