

No relevant graphs to display

RECOMMENDATION	PROBLEMATIC TEST RESULTS			
We recommend you convice the filters on this	Sample Status	ABNORMAL	ABNORMAL	ABNORMAL

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
Debris	scalar	*Visual	NONE	A MODER	A MODER	NONE	

Customer Id: EOGMID Sample No.: TO60001644 Lab Number: 06008404 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Filter			?	We recommend you service the filters on this component.		
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.		

HISTORICAL DIAGNOSIS



06 Sep 2023 Diag: Jonathan Hester

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

15 Aug 2023 Diag: Don Baldridge

We recommend y component wear acceptable for this

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

02 Jun 2022 Diag: Jonathan Hester



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

Sample Rating Trend



Area JAL NM Machine Id MRC-203 Component Compressor Fluid NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		TO60001644	TO60001450	TO60001177	
Sample Date		Client Info		02 Nov 2023	06 Sep 2023	15 Aug 2023	
Machine Age	hrs	Client Info		22890	21546	21025	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	1	3	1	
Chromium	ppm	ASTM D5185m	>10	0	0	0	
Nickel	ppm	ASTM D5185m		0	0	0	
Titanium	ppm	ASTM D5185m		0	0	0	
Silver	ppm	ASTM D5185m		0	0	0	
Aluminum	ppm	ASTM D5185m	>25	<1	0	<1	
Lead	ppm	ASTM D5185m	>25	5	3	3	
Copper	ppm	ASTM D5185m		34	31	30	
Tin	ppm	ASTM D5185m	>15	2	2	2	
Vanadium	ppm	ASTM D5185m	-	- <1	0	- <1	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		52	51	52	
Barium	ppm	ASTM D5185m		0	0	0	
Molybdenum	ppm	ASTM D5185m		3	3	3	
Manganese	ppm	ASTM D5185m		<1	<1	0	
Magnesium	ppm	ASTM D5185m		13	16	11	
Calcium	ppm	ASTM D5185m		1301	1228	1349	
Phosphorus	ppm	ASTM D5185m		329	281	301	
Zinc	ppm	ASTM D5185m		376	328	340	
Sulfur	ppm	ASTM D5185m		2089	2247	2229	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	2	4	1	
Sodium	ppm	ASTM D5185m		3	4	3	
Potassium	ppm	ASTM D5185m	>20	<1	0	0	
Water	%	ASTM D6304	>0.1	0.015	0.008	0.011	
ppm Water	ppm	ASTM D6304	>1000	151.9	84.8	119.8	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647	>10000			A 21022	
Particles >6µm		ASTM D7647	>2500			▲ 6472	
Particles >14 μ m		ASTM D7647	>320			3 72	
Particles >21µm		ASTM D7647	>80			76	
Particles >38µm		ASTM D7647	>20			1	
Particles >71µm		ASTM D7647	>4			1	
Oil Cleanliness		ISO 4406 (c)	>20/18/15			▲ 22/20/16	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.12	0.799	0.624	

Contact/Location: HERMAN GARZA - EOGMID



140

120

60 Abnorm


4(

20

Jun2/22

100 (40°C)

OIL ANALYSIS REPORT




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	🔺 MODER	🔺 MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		127	124	126
Visc @ 100°C	cSt	ASTM D445		13.3	12.6	13.1
Viscosity Index (VI)	Scale	ASTM D2270		98	92	97
SAMPLE IMAGES		method	limit/base	current	history1	history2





Bottom



Contact/Location: HERMAN GARZA - EOGMID