


# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**MRC-302**  
 Component  
**Natural Gas Engine**  
 Fluid  
**NOT GIVEN (--- GAL)**

**DIAGNOSIS**

**Recommendation**

Resample at the next service interval to monitor. Please specify the component make and model with your next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

**Wear**

All component wear rates are normal.

**Contamination**

There is no indication of any contamination in the oil.

**Fluid Condition**

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>TO60001736</b>	TO60001649	TO60001428
Sample Date	Client Info			<b>04 Nov 2023</b>	12 Oct 2023	05 Sep 2023
Machine Age	hrs	Client Info		<b>4168</b>	3601	2281
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed		Client Info		<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>2</b>	2	3
Chromium	ppm	ASTM D5185m	>4	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m	>2	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>9	<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185m	>30	<b>9</b>	6	2
Copper	ppm	ASTM D5185m	>35	<b>2</b>	2	2
Tin	ppm	ASTM D5185m	>4	<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0





ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>75</b>	85	92
Barium	ppm	ASTM D5185m		<b>0</b>	0	<1
Molybdenum	ppm	ASTM D5185m		<b>&lt;1</b>	1	2
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185m		<b>18</b>	17	24
Calcium	ppm	ASTM D5185m		<b>1103</b>	1190	1190
Phosphorus	ppm	ASTM D5185m		<b>174</b>	262	257
Zinc	ppm	ASTM D5185m		<b>276</b>	291	287
Sulfur	ppm	ASTM D5185m		<b>1080</b>	1006	1146

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	<b>&lt;1</b>	<1	<1
Sodium	ppm	ASTM D5185m		<b>2</b>	1	3
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	0	2

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>9.3</b>	9.2	10.0
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>19.4</b>	19.0	21.5

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>15.4</b>	14.9	15.6
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>1.15</b>	1.11	1.04
Base Number (BN)	mg KOH/g	ASTM D2896		<b>3.31</b>	3.48	3.36





# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	<b>141</b>	140	137
Visc @ 100°C	cSt	ASTM D445	<b>13.9</b>	13.8	13.7
Viscosity Index (VI)	Scale	ASTM D2270	<b>94</b>	94	95

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO60001736 **Received** : 15 Nov 2023  
**Lab Number** : 06008524 **Diagnosed** : 17 Nov 2023  
**Unique Number** : 10742286 **Diagnostician** : Wes Davis  
**Test Package** : IND 2 ( Additional Tests: FT-IR, KV40, VI )

**MIDLAND - EOG RESOURCES INC.**  
 5509 CHAMPIONS DRIVE  
 MIDLAND, TX  
 US 79706  
 Contact: HERMAN GARZA  
 herman\_garza@eogresources.com  
 T: (432)686-3600  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)