


# OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id  
**MRC-322**  
Component  
**Natural Gas Engine**  
Fluid  
**NOT GIVEN (--- GAL)**

## DIAGNOSIS

**Recommendation**  
Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

**Wear**  
All component wear rates are normal.

**Contamination**  
There is no indication of any contamination in the oil.

**Fluid Condition**  
The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>TO60001752</b>	TO60001671	TO60001434
Sample Date	Client Info		<b>05 Nov 2023</b>	12 Oct 2023	05 Sep 2023
Machine Age	hrs	Client Info	<b>5267</b>	4575	3065
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed		Client Info	<b>N/A</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>3</b>	2	5
Chromium	ppm	ASTM D5185m >4	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m >2	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m >3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >9	<b>&lt;1</b>	2	<1
Lead	ppm	ASTM D5185m >30	<b>6</b>	6	1
Copper	ppm	ASTM D5185m >35	<b>2</b>	2	1
Tin	ppm	ASTM D5185m >4	<b>&lt;1</b>	<1	<1
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	<1	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>83</b>	93	98
Barium	ppm	ASTM D5185m	<b>0</b>	10	<1
Molybdenum	ppm	ASTM D5185m	<b>0</b>	1	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185m	<b>11</b>	11	15
Calcium	ppm	ASTM D5185m	<b>1238</b>	1294	1363
Phosphorus	ppm	ASTM D5185m	<b>194</b>	297	278
Zinc	ppm	ASTM D5185m	<b>285</b>	308	305
Sulfur	ppm	ASTM D5185m	<b>1130</b>	1390	1323

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	<b>1</b>	2	2
Sodium	ppm	ASTM D5185m	<b>2</b>	0	3
Potassium	ppm	ASTM D5185m >20	<b>0</b>	2	1





## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624 >20	<b>10.1</b>	10.0	10.0
Sulfation	Abs/.1mm	*ASTM D7415 >30	<b>17.7</b>	17.3	16.6

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	<b>17.3</b>	17.2	16.1
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>1.29</b>	1.33	1.26
Base Number (BN)	mg KOH/g	ASTM D2896	<b>3.50</b>	3.58	3.28





# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	147	148	145
Visc @ 100°C	cSt	ASTM D445	14.4	14.2	14.0
Viscosity Index (VI)	Scale	ASTM D2270	95	92	92

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO60001752 **Received** : 15 Nov 2023  
**Lab Number** : 06008535 **Diagnosed** : 17 Nov 2023  
**Unique Number** : 10742297 **Diagnostician** : Wes Davis  
**Test Package** : IND 2 ( Additional Tests: FT-IR, KV40, VI )

**MIDLAND - EOG RESOURCES INC.**  
 5509 CHAMPIONS DRIVE  
 MIDLAND, TX  
 US 79706  
 Contact: HERMAN GARZA  
 herman\_garza@eogresources.com  
 T: (432)686-3600  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)