




PROBLEM SUMMARY

Sample Rating Trend




WEAR




Area
NEIL N DIEHL
 Machine Id
[NEIL N DIEHL] 008 639030-8
 Component
Starboard Genset
 Fluid
CHEVRON DELO 400 XLE 15W40 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Non-ferrous Metals



▲ Viscosity @ 100°C



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | | | ABNORMAL | ABNORMAL | ABNORMAL |
|---------------|-----|-------------|------|-----------------|----------|----------|
| Copper | ppm | ASTM D5185m | >70 | ▲ 86 | ▲ 53 | ▲ 44 |
| Visc @ 100°C | cSt | ASTM D445 | 14.9 | ▲ 11.9 | ▲ 12.3 | ▲ 12.0 |

Customer Id: INGPAD
 Sample No.: MW0058475
 Lab Number: 06008839
 Test Package: MAR 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Sean Felton +1 919-379-4092
sfelton@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|---------------|--------|------|---------|---|
| Change Fluid | --- | --- | ? | Oil and filter change at the time of sampling has been noted. |
| Change Filter | --- | --- | ? | Oil and filter change at the time of sampling has been noted. |

HISTORICAL DIAGNOSIS

09 Sep 2023 Diag: Don Baldrige

WEAR



[view report](#)



11 Aug 2023 Diag: Jonathan Hester

WEAR



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the oil. The oil viscosity is lower than normal. The BN result indicates that there is suitable alkalinity remaining in the oil. Confirm oil type.

[view report](#)



08 Jul 2023 Diag: Sean Felton

WEAR



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The copper level has decreased, but is still abnormal. In the absence of other significant wear metals, suspect copper due to sources other than wear (i.e. cooling core). All other component wear rates are normal. Light fuel dilution occurring. Fuel is present in the oil and is lowering the viscosity. The BN result indicates that there is suitable alkalinity remaining in the oil.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
NEIL N DIEHL
 Machine Id
[NEIL N DIEHL] 008 639030-8
 Component
Starboard Genset
 Fluid
CHEVRON DELO 400 XLE 15W40 (--- GAL)

DIAGNOSIS

▲ Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

▲ Wear

The copper level is abnormal. In the absence of other significant wear metals, suspect copper due to sources other than wear (i.e. cooling core). All other component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

▲ Fluid Condition

The oil viscosity is lower than normal. The BN result indicates that there is suitable alkalinity remaining in the oil. Confirm oil type.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | MW0058475 | MW0059905 | MW0059896 |
| Sample Date | Client Info | | 13 Oct 2023 | 09 Sep 2023 | 11 Aug 2023 |
| Machine Age | hrs | Client Info | 2805 | 2423 | 2063 |
| Oil Age | hrs | Client Info | 382 | 354 | 427 |
| Oil Changed | Client Info | | Changed | Changed | Changed |
| Sample Status | | | ABNORMAL | ABNORMAL | ABNORMAL |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|--------|-----------|------------|------------|----------|----------|
| Glycol | WC Method | | NEG | NEG | NEG |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|--------------|-------------|-------------|
| Iron | ppm | ASTM D5185m >50 | 4 | 7 | 5 |
| Chromium | ppm | ASTM D5185m >4 | 0 | <1 | <1 |
| Nickel | ppm | ASTM D5185m >2 | 0 | <1 | 0 |
| Titanium | ppm | ASTM D5185m | 0 | <1 | <1 |
| Silver | ppm | ASTM D5185m >5 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m >12 | 3 | 3 | 0 |
| Lead | ppm | ASTM D5185m >17 | 0 | <1 | 0 |
| Copper | ppm | ASTM D5185m >70 | ▲ 86 | ▲ 53 | ▲ 44 |
| Tin | ppm | ASTM D5185m >15 | <1 | <1 | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | <1 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | <1 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|------------------|-------------|----------|----------|
| Boron | ppm | ASTM D5185m | 260 | 330 | 280 |
| Barium | ppm | ASTM D5185m | 0 | 4 | 0 |
| Molybdenum | ppm | ASTM D5185m | 109 | 114 | 115 |
| Manganese | ppm | ASTM D5185m | 1 | 1 | 1 |
| Magnesium | ppm | ASTM D5185m | 594 | 565 | 665 |
| Calcium | ppm | ASTM D5185m | 1454 | 1519 | 1665 |
| Phosphorus | ppm | ASTM D5185m 760 | 556 | 622 | 660 |
| Zinc | ppm | ASTM D5185m 830 | 738 | 724 | 801 |
| Sulfur | ppm | ASTM D5185m 2770 | 2320 | 2255 | 2980 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-----------------|----------------|----------|----------|
| Silicon | ppm | ASTM D5185m >25 | 6 | 7 | 6 |
| Sodium | ppm | ASTM D5185m | <1 | 2 | 1 |
| Potassium | ppm | ASTM D5185m >20 | 0 | <1 | 0 |
| Fuel | % | ASTM D3524 >4.0 | <1.0 | <1.0 | <1.0 |

INFRA-RED





| | method | limit/base | current | history1 | history2 |
|-----------|----------|-----------------|-------------|----------|----------|
| Soot % | % | *ASTM D7844 | 0.1 | 0.1 | 0.1 |
| Nitration | Abs/cm | *ASTM D7624 >20 | 7.4 | 6.8 | 7.6 |
| Sulfation | Abs/.1mm | *ASTM D7415 >30 | 22.7 | 21.9 | 22.4 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|-----------------|-------------|----------|----------|
| Oxidation | Abs/.1mm | *ASTM D7414 >25 | 16.8 | 15.7 | 16.7 |
| Base Number (BN) | mg KOH/g | ASTM D2896 10.7 | 8.4 | 8.4 | 8.7 |







OIL ANALYSIS REPORT



| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.1 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 100°C | cSt | ASTM D445 | 14.9 | ▲ 11.9 | ▲ 12.3 |

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : MW0058475 **Received** : 15 Nov 2023
Lab Number : 06008839 **Diagnosed** : 16 Nov 2023
Unique Number : 10742601 **Diagnostician** : Sean Felton
Test Package : MAR 2 (Additional Tests: FuelDilution, PercentFuel)

INGRAM BARGE
 900 S 3RD ST
 PADUCAH, KY
 US 42003
 Contact: ALLEN WILLHELM
 allen.willhelm@ingrambargo.com
 T: (270)415-4467
 F: (615)695-3697

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)