


# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Area  
**C-4001B**  
Machine Id  
**C-4001B**  
Component  
**Compressor**  
Fluid  
**NOT GIVEN (--- LTR)**

**DIAGNOSIS**

**Recommendation**

Resample at the next service interval to monitor.

**Wear**

All component wear rates are normal.

**Contamination**

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>TO60000697</b>	TO60000702	TO60000696
Sample Date	Client Info			<b>05 Oct 2023</b>	21 Sep 2023	20 Jul 2023
Machine Age	hrs	Client Info		<b>16007</b>	15756	15120
Oil Age	hrs	Client Info		<b>16007</b>	15756	15120
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>5</b>	5	6
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m		<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>25	<b>1</b>	1	0
Lead	ppm	ASTM D5185m	>25	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>50	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185m	>15	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	0	2
Barium	ppm	ASTM D5185m		<b>11</b>	11	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m		<b>2</b>	3	2
Calcium	ppm	ASTM D5185m		<b>2</b>	2	<1
Phosphorus	ppm	ASTM D5185m		<b>668</b>	654	606
Zinc	ppm	ASTM D5185m		<b>8</b>	12	6
Sulfur	ppm	ASTM D5185m		<b>627</b>	654	1419

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>1</b>	<1	2
Sodium	ppm	ASTM D5185m		<b>0</b>	0	2
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	<1	1
Water	%	ASTM D6304	>0.1	<b>0.007</b>	0.008	0.009
ppm Water	ppm	ASTM D6304	>1000	<b>70.8</b>	85.6	99.5

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<b>4352</b>	5709	9142
Particles >6µm		ASTM D7647	>2500	<b>550</b>	726	1927
Particles >14µm		ASTM D7647	>320	<b>18</b>	18	114
Particles >21µm		ASTM D7647	>80	<b>5</b>	2	29
Particles >38µm		ASTM D7647	>20	<b>0</b>	0	1
Particles >71µm		ASTM D7647	>4	<b>0</b>	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<b>19/16/11</b>	20/17/11	20/18/14

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.86</b>	0.84	0.88


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	<b>45.8</b>	47.6	45.7
Visc @ 100°C	cSt	ASTM D445	<b>8</b>	7.9	8
Viscosity Index (VI)	Scale	ASTM D2270	<b>147</b>	135	147

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO60000697 **Received** : 15 Nov 2023  
**Lab Number** : **06009107** **Diagnosed** : 19 Nov 2023  
**Unique Number** : 10742869 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**TRANSCONTINENTAL GAS PIPELINE - CARLSTADT**  
 718 PATTERSON PLANK RD  
 CARLSTADT, NJ  
 US 07072  
 Contact: **RICHIE GUIMOND**  
 richie.guimond@williams.com  
 T: (830)267-1263  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)