PROBLEM SUMMARY

Area
[PRE CHANGE]
Machine Id
WW ACP (S/N CBV578862)
Component
Air Compressor
Fluid
XAERUS AAT 46N (--- GAL)

Sample Rating Trend



ISO

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	NORMAL	NORMAL
Particles >4µm		ASTM D7647	>10000	▲ **58132**	847	6528
Particles >6µm		ASTM D7647	>2500	▲ **17606**	170	1428
Particles >14µm		ASTM D7647	>320	▲ **1318**	11	87
Particles >21µm		ASTM D7647	>80	▲ **362**	4	30
Oil Cleanliness		ISO 4406 (c)	>20/18/15	▲ **23/21/18**	17/15/11	20/18/14

Customer Id: PILNACFRE
Sample No.: USPM31293
Lab Number: 06009681
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Nov 17 2023	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

09 Oct 2023 Diag: Doug Bogart

NORMAL

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

29 Jul 2023 Diag: Doug Bogart

NORMAL

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

16 Feb 2023 Diag: Doug Bogart

NORMAL

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
[PRE CHANGE]
Machine Id
WW ACP (S/N CBV578862)
Component
Air Compressor
Fluid
XAERUS AAT 46N (--- GAL)

DIAGNOSIS

Recommendation
We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a high amount of particulates present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**USPM31293**	USP0001391	USP0000944
Sample Date		Client Info		**14 Nov 2023**	09 Oct 2023	29 Jul 2023
Machine Age	hrs	Client Info		**30404**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	**3**	0	0
Chromium	ppm	ASTM D5185m	>4	**0**	0	0
Nickel	ppm	ASTM D5185m	>4	**0**	0	0
Titanium	ppm	ASTM D5185m		**0**	0	<1
Silver	ppm	ASTM D5185m		**0**	0	0
Aluminum	ppm	ASTM D5185m	>10	**2**	3	0
Lead	ppm	ASTM D5185m	>20	**0**	0	0
Copper	ppm	ASTM D5185m	>40	**1**	<1	1
Tin	ppm	ASTM D5185m	>5	**0**	<1	0
Vanadium	ppm	ASTM D5185m		**0**	0	<1
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	0
Barium	ppm	ASTM D5185m		**0**	0	0
Molybdenum	ppm	ASTM D5185m		**0**	0	0
Manganese	ppm	ASTM D5185m		**0**	0	0
Magnesium	ppm	ASTM D5185m		**<1**	0	<1
Calcium	ppm	ASTM D5185m		**<1**	1	0
Phosphorus	ppm	ASTM D5185m		**2**	1	0
Zinc	ppm	ASTM D5185m		**0**	6	0
Sulfur	ppm	ASTM D5185m		**0**	4	0

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	**0**	0	<1
Sodium	ppm	ASTM D5185m		**<1**	2	2
Potassium	ppm	ASTM D5185m	>20	**1**	0	1
Water	%	ASTM D6304	>0.6	**0.012**	0.008	0.006
ppm Water	ppm	ASTM D6304	>6000	**128.8**	82.0	64.2

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	▲ **58132**	847	6528
Particles >6µm		ASTM D7647	>2500	▲ **17606**	170	1428
Particles >14µm		ASTM D7647	>320	▲ **1318**	11	87
Particles >21µm		ASTM D7647	>80	▲ **362**	4	30
Particles >38µm		ASTM D7647	>20	**20**	0	2
Particles >71µm		ASTM D7647	>4	**1**	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	▲ **23/21/18**	17/15/11	20/18/14

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		**0.37**	0.49	0.47

OIL ANALYSIS REPORT











VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		**54.5**	54.0	55.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS











Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM31293
Lab Number : 06009681
Unique Number : 10743443
Test Package : IND 2

Received : 16 Nov 2023
Diagnosed : 17 Nov 2023
Diagnostician : Doug Bogart

Certificate L2367

PILGRIMS
928 MARTIN LUTHER KING JR BLVD
NACOGDOCHES, TX
US 75961
Contact: KERRI SULLIVAN

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: (936)558-6928