




PROBLEM SUMMARY

Area
PLATE FREEZER
 Machine Id
PLATE FRZR 1-5

Component
Hydraulic System
 Fluid
LUBRIPLATE L0867-062 (--- GAL)



Sample Rating Trend



WATER



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	SEVERE
Water	%	ASTM D6304	>0.05	▲ 0.179	● 1.11	● 3.01
ppm Water	ppm	ASTM D6304	>500	▲ 1794.1	● 11100	● 30100
Particles >4µm		ASTM D7647	>5000	▲ 10981	▲ 10305	---
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ 21/17/13	▲ 21/16/13	---

Customer Id: CONRUS
 Sample No.: USP0003664
 Lab Number: 06009691
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

19 Aug 2023 Diag: Doug Bogart

WATER



We advise that you check for the source of water entry. We advise that you perform a filter service and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. Appearance is milky. There is a high amount of silt (particulates < 6 microns in size) present in the oil. There is a high concentration of water present in the oil. The AN level is acceptable for this fluid.

view report



19 Apr 2023 Diag: Doug Bogart

WATER



We advise that you check for the source of water entry. We advise that you perform a filter service and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles and water present in this sample. All component wear rates are normal. Appearance is milky. There is a high concentration of water present in the oil. Moderate concentration of visible sediment present in the oil. The AN level is acceptable for this fluid.

view report



25 Jan 2023 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. Appearance is milky. There is a high concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
PLATE FREEZER
Machine Id
PLATE FRZR 1-5

Component
Hydraulic System
Fluid
LUBRIPLATE L0867-062 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 6 microns in size) present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USP0003664	USP0000567	USP248825
Sample Date	Client Info	15 Nov 2023	19 Aug 2023	19 Apr 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	SEVERE	SEVERE

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >20	3	8	17
Chromium	ppm	ASTM D5185m >20	0	<1	<1
Nickel	ppm	ASTM D5185m >20	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >20	<1	0	<1
Lead	ppm	ASTM D5185m >20	0	0	0
Copper	ppm	ASTM D5185m >20	<1	1	5
Tin	ppm	ASTM D5185m >20	0	<1	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	64	62	65
Barium	ppm	ASTM D5185m	0	<1	<1
Molybdenum	ppm	ASTM D5185m	<1	0	<1
Manganese	ppm	ASTM D5185m	0	<1	<1
Magnesium	ppm	ASTM D5185m	2	4	4
Calcium	ppm	ASTM D5185m	54	80	138
Phosphorus	ppm	ASTM D5185m	168	200	232
Zinc	ppm	ASTM D5185m	37	124	248
Sulfur	ppm	ASTM D5185m	833	1091	1360

CONTAMINANTS






method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	7	3	9
Sodium	ppm	ASTM D5185m	0	4	7
Potassium	ppm	ASTM D5185m >20	1	<1	<1
Water	%	ASTM D6304 >0.05	▲ 0.179	1.11	3.01
ppm Water	ppm	ASTM D6304 >500	▲ 1794.1	11100	30100

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	▲ 10981	▲ 10305	---
Particles >6µm	ASTM D7647 >1300	1118	556	---
Particles >14µm	ASTM D7647 >160	76	42	---
Particles >21µm	ASTM D7647 >40	21	12	---
Particles >38µm	ASTM D7647 >10	0	1	---
Particles >71µm	ASTM D7647 >3	0	0	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 21/17/13	▲ 21/16/13	---

FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.69	0.83	0.89








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	▲ MODER
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ MILKY	▲ MILKY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	33.0	30.8	25.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP0003664 **Received** : 16 Nov 2023
Lab Number : 06009691 **Diagnosed** : 17 Nov 2023
Unique Number : 10743453 **Diagnostician** : Doug Bogart
Test Package : IND 2

CONAGRA FROZEN FOODS CO
 RUSSELLVILLE, AR
 US
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: